

## **Certificate**

### **Certified Passive House Component**

for cool, temperate climates; valid until 31.12.2013

Category: Window Frame

Manufacturer: Casagrande Woodworks, Inc.

Paso Robles, CA 93446, USA

Product name: Synergist

# This certificate was awarded based on the following criteria:

Given a Ug value of 0.70 W/(m<sup>2</sup>K) and a window size of 1.23 m by 1.48 m,

 $U_{W} = 0.79 \text{ W/(m}^{2}\text{K}) \leq 0.80 \text{ W/(m}^{2}\text{K})$ 

Taking into account the installation based thermal bridges and provided that the installation is, with regard to the thermal bridges, equal or better than shown in the data sheet, the window meets the following criterion.

 $U_{W,installed} \leq 0.85 \text{ W/(m}^2\text{K)}$ 


#### Thermal data

	U <sub>f</sub> -value [W/(m <sup>2</sup> K)]	Width [mm]	Ψ <sub>g</sub> [W/(mK)]	f <sub>Rsi=0.25</sub>
Spacer			Swisspace	r Ultimate*
Bottom	0.84	98	0.020	0.70
Side/top	0.84	98	0.020	0.70

\*Spacers of lower thermal quality, especially those made of aluminium, lead to significantly higher thermal losses and lower temperature factors.

For further information, please see the data sheet

Passive House Institute Dr. Wolfgang Feist 64283 Darmstadt GERMANY








Data Sheet Casagrande Woodworks, Inc., Synergist

Manufacturer Casagrande Woodworks, Inc.

4230 Cloud Way, Paso Robles, CA 93446, USA

Tel.: + 1 805 226 2040

Email: Jeff@casagrandewoodworks.com, www.casagrandewoodworks.com




#### **Description**

Timber window frame (spruce, fir 0,11 W/(mK)) with cork insulation in the frame and Spaceloft (0,016 W/(mK)) in the glazing rebate. Secondary seal: Butyl (0,24 W/(mK)). Pane thickness: 44 mm (4/16/4/16/4), Rebate depth: 15 mm.

#### Thermal data for the window frame

	U <sub>f</sub> -value	Width	$\Psi_{g}$	f <sub>Rsi=0.25</sub>
	$[W/(m^2K)]$	[mm]	[W/(mK)]	[-]
Spacer			Swisspacer Ultimate*	
Bottom	0.84	98	0.020	0.70
Side/Top	0.84	98	0.020	0.70
Flying Mullion	0.84	144	0.020	0.71




<sup>\*</sup> Spacers of lower thermal quality lead to higher thermal losses and lower glass edge temperatures.



### Data Sheet Casagrande Woodworks, Inc., Synergist

#### Installation



## Installation based thermal bridge $\Psi_{\mbox{\tiny instal.}}$ in Passive House suitable walls

Position		EIFS	Timber construction wall	Insulated formwork blocks
Bottom	[W/(mK)]	0.017	0.009	0.016
Side/Top	[W/(mK)]	0.005	-0.001	0.009
U <sub>W,instal.</sub>	[W/(m <sup>2</sup> K)]	0.81	0.79	0.82

#### **Explanatory notes**

The window U-values were calculated based on a 1.23 m by 1.48 m window  $U_g = 0.70 \text{ W/(m}^2\text{K})$ . If better glazing is used, the window U-values decrease as follows:

U Glazing	$\mathbf{U_g}$ [W/(m <sup>2</sup> K)]	0.64	0.58	0.54
U Window	$\mathbf{U}_{\mathbf{W}} \left[ \mathbf{W}/(\mathbf{m}^2 \mathbf{K}) \right]$	0.75	0.70	0.67

Depending on the thermal losses through opaque elements, transparent components are categorised according to efficiency classes. These thermal losses include the losses through the frame, the frame width, the thermal bridge at the glass edge as well as the length of the glass edge. Certificates for arctic regions are too valid vor cold, certificates for cold regions are too valid for cool, temperate zones.

Please ask the manufacturer for a detailed report containing all calculations and results.

For further information, please visit www.passivehouse.com or www.passipedia.org.