

*91 Hyde Blvd
HVAC Load Calculations*

for

Liz Kormos



Prepared By:

Saturday, May 26, 2012



Project Report

General Project Information

Project Title: 91 Hyde Blvd
 Project Date: Sunday, April 15, 2012
 Client Name: Liz Kormos

Design Data

Reference City: Albany, New York
 Building Orientation: Front door faces West
 Daily Temperature Range: Medium
 Latitude: 42 Degrees
 Elevation: 275 ft.
 Altitude Factor: 0.990
 Elevation Sensible Adj. Factor: 1.000
 Elevation Total Adj. Factor: 1.000
 Elevation Heating Adj. Factor: 1.000
 Elevation Heating Adj. Factor: 1.000

| | Outdoor Dry Bulb | Outdoor Wet Bulb | Outdoor Rel.Hum | Indoor Rel.Hum | Indoor Dry Bulb | Grains Difference |
|---------|---------------------|---------------------|--------------------|-------------------|--------------------|----------------------|
| Winter: | 1 | 0.31 | 80% | n/a | 70 | n/a |
| Summer: | 88 | 72 | 47% | 50% | 75 | 28 |

Check Figures

| | | | |
|------------------------------|--------|---------------------|-------|
| Total Building Supply CFM: | 794 | CFM Per Square ft.: | 0.382 |
| Square ft. of Room Area: | 2,077 | Square ft. Per Ton: | 1,149 |
| Volume (ft³) of Cond. Space: | 17,612 | | |

Building Loads

| | | |
|---|-------------|--|
| Total Heating Required Including Ventilation Air: | 14,594 Btuh | 14.594 MBH |
| Total Sensible Gain: | 17,551 Btuh | 81 % |
| Total Latent Gain: | 4,150 Btuh | 19 % |
| Total Cooling Required Including Ventilation Air: | 21,701 Btuh | 1.81 Tons (Based On Sensible + Latent) |

Notes

Rhvac is an ACCA approved Manual J and Manual D computer program.
 Calculations are performed per ACCA Manual J 8th Edition, Version 2, and ACCA Manual D.
 All computed results are estimates as building use and weather may vary.
 Be sure to select a unit that meets both sensible and latent loads.



Miscellaneous Report

| System 1 House Input Data | Outdoor Dry Bulb | Outdoor Wet Bulb | Outdoor Rel.Hum | Indoor Rel.Hum | Indoor Dry Bulb | Grains Difference |
|--------------------------------|---------------------|---------------------|--------------------|-------------------|--------------------|----------------------|
| Winter: | 1 | 0.31 | 80% | n/a | 70 | n/a |
| Summer: | 88 | 72 | 47% | 50% | 75 | 28.13 |
| System 2 Mudroom Input Data | Outdoor Dry Bulb | Outdoor Wet Bulb | Outdoor Rel.Hum | Indoor Rel.Hum | Indoor Dry Bulb | Grains Difference |
| Winter: | 1 | 0.31 | 80% | n/a | 50 | n/a |
| Summer: | 88 | 72 | 47% | 50% | 75 | 28.13 |

Duct Sizing Inputs

| | Main Trunk | Runouts |
|-------------------|-----------------------|-----------------------|
| Calculate: | Yes | Yes |
| Use Schedule: | Yes | Yes |
| Roughness Factor: | 0.00300 | 0.01000 |
| Pressure Drop: | 0.1000 in.wg./100 ft. | 0.1000 in.wg./100 ft. |
| Minimum Velocity: | 650 ft./min | 450 ft./min |
| Maximum Velocity: | 900 ft./min | 750 ft./min |
| Minimum Height: | 0 in. | 0 in. |
| Maximum Height: | 0 in. | 0 in. |

Outside Air Data

| | Winter | Summer |
|------------------------------|--|--|
| Infiltration Specified: | 0.117 AC/hr 34 CFM | 0.053 AC/hr 15 CFM |
| Infiltration Actual: | 0.035 AC/hr | 0.012 AC/hr |
| Above Grade Volume: | X 17,612 Cu.ft. 625 Cu.ft./hr X 0.0167 | X 17,612 Cu.ft. 205 Cu.ft./hr X 0.0167 |
| Total Building Infiltration: | 10 CFM | 3 CFM |
| Total Building Ventilation: | 89 CFM | 89 CFM |

---System 1---

| | | |
|--|--|--|
| Infiltration & Ventilation Sensible Gain Multiplier: | 14.16 | = (1.10 X 0.990 X 13.00 Summer Temp. Difference) |
| Infiltration & Ventilation Latent Gain Multiplier: | 18.94 | = (0.68 X 0.990 X 28.13 Grains Difference) |
| Infiltration & Ventilation Sensible Loss Multiplier: | 75.15 | = (1.10 X 0.990 X 69.00 Winter Temp. Difference) |
| Winter Infiltration Specified: | 0.085 AC/hr (24 CFM), Construction: Unknown, Fireplaces: 2, 7 CFM, Tight | |
| Summer Infiltration Specified: | 0.043 AC/hr (12 CFM), Construction: Unknown | |

---System 2---

| | | |
|--|---|--|
| Infiltration & Ventilation Sensible Gain Multiplier: | 14.16 | = (1.10 X 0.990 X 13.00 Summer Temp. Difference) |
| Infiltration & Ventilation Latent Gain Multiplier: | 18.94 | = (0.68 X 0.990 X 28.13 Grains Difference) |
| Infiltration & Ventilation Sensible Loss Multiplier: | 53.37 | = (1.10 X 0.990 X 49.00 Winter Temp. Difference) |
| Winter Infiltration Specified: | 0.300 AC/hr (3 CFM), Construction: Unknown, Fireplaces: 2, 7 CFM, Tight | |
| Summer Infiltration Specified: | 0.300 AC/hr (3 CFM), Construction: Unknown | |




Load Preview Report

| Scope | Net Ton | ft. ² /Ton | Area | Sen Gain | Lat Gain | Net Gain | Sen Loss | Sys Htg CFM | Sys Clg CFM | Sys Act CFM | Duct Size |
|--|------------|--------------------------|-------|-------------|-------------|-------------|-------------|-------------------|-------------------|-------------------|--------------|
| Building | 1.81 | 1,149 | 2,077 | 17,551 | 4,150 | 21,701 | 14,594 | 174 | 794 | 794 | |
| System 1 | 1.72 | 1,160 | 1,991 | 16,715 | 3,885 | 20,601 | 13,169 | 155 | 756 | 756 | 10x15 |
| Ventilation | | | | 252 | 1,685 | 1,937 | 1,338 | | | | |
| Blower | | | | 682 | | 682 | | | | | |
| Zone 1 | | | 384 | 3,095 | 400 | 3,495 | 2,562 | 34 | 147 | 147 | 5x5 |
| 1-Master Bedroom | | | 182 | 2,486 | 400 | 2,886 | 1,444 | 19 | 118 | 118 | 1-6 |
| 2-Master Closet | | | 87 | 415 | 0 | 415 | 661 | 9 | 20 | 20 | 1-4 |
| 3-Master WC | | | 52 | 138 | 0 | 138 | 383 | 5 | 7 | 7 | 1-4 |
| 4-Master Bath | | | 63 | 55 | 0 | 55 | 74 | 1 | 3 | 3 | 1-4 |
| Zone 2 | | | 774 | 9,302 | 1,000 | 10,302 | 3,894 | 51 | 441 | 441 | 8x12 |
| 12-East Office | | | 171 | 2,283 | 200 | 2,483 | 1,000 | 13 | 108 | 108 | 1-6 |
| 13-West Office | | | 205 | 3,594 | 200 | 3,794 | 1,275 | 17 | 170 | 170 | 2-5 |
| 14-Away Room | | | 136 | 1,309 | 400 | 1,709 | 680 | 9 | 62 | 62 | 1-5 |
| 15-2F Hall | | | 128 | 531 | 200 | 731 | 401 | 5 | 25 | 25 | 1-4 |
| 16-Guest Bath | | | 68 | 203 | 0 | 203 | 385 | 5 | 10 | 10 | 1-4 |
| 17-Mechanical Room | | | 32 | 1,352 | 0 | 1,352 | 113 | 1 | 64 | 64 | 1-5 |
| 18-Closet | | | 34 | 30 | 0 | 30 | 40 | 1 | 1 | 1 | 1-4 |
| Zone 3 | | | 833 | 9,265 | 800 | 10,065 | 5,375 | 71 | 439 | 439 | 8x12 |
| 5-Kitchen | | | 136 | 2,084 | 400 | 2,484 | 524 | 7 | 99 | 99 | 1-6 |
| 6-Pantry | | | 79 | 97 | 0 | 97 | 255 | 3 | 5 | 5 | 1-4 |
| 8-Dining | | | 198 | 2,431 | 400 | 2,831 | 1,053 | 14 | 115 | 115 | 1-6 |
| 9-Living Room | | | 305 | 4,257 | 0 | 4,257 | 2,506 | 33 | 202 | 202 | 2-6 |
| 10-Entry | | | 89 | 293 | 0 | 293 | 755 | 10 | 14 | 14 | 1-4 |
| 11-Half Bathroom | | | 26 | 103 | 0 | 103 | 282 | 4 | 5 | 5 | 1-4 |
| System 2 | 0.09 | 938 | 86 | 835 | 265 | 1,100 | 1,425 | 19 | 38 | 38 | 4x4 |
| Zone 1 | | | 86 | 835 | 265 | 1,100 | 1,425 | 19 | 38 | 38 | 4x4 |
| 7-Mudroom | | | 86 | 835 | 265 | 1,100 | 1,425 | 19 | 38 | 38 | 1-4 |
| Sum of room airflows may be greater than system airflow because system has multiple zones. | | | | | | | | | | | |



System 1 - House - Adequate Exposure Diversity Test

Test For Adequate Exposure Diversity



AED Calculation Summary

--- SYSTEM DOES NOT HAVE ADEQUATE EXPOSURE DIVERSITY. ---

System is on N, E, S, W rosette.

Peak load exceeds 12-hour average load by 53.3%.

AED Excursion (amount by which peak exceeds 1.3 x average): 1,633 Btuh


Definition: A system has adequate exposure diversity if the peak-hour glass load for the entire conditioned space does not exceed the average glass load for the entire conditioned space by more than 30 percent.

(System Concept Warning for excursion equal to or exceeding 1.5 x baseline) This application has glass areas that produced large heat gains for part of the day. Variable air volume devices are required to overcome large spikes in solar gain for one or more rooms. Install a zoned system or provide zone control (individual, motorized, thermostatically controlled dampers) for problem rooms. Single speed equipment may not be suitable for the application.



System 2 - Mudroom - Adequate Exposure Diversity Test

Test For Adequate Exposure Diversity



AED Calculation Summary

--- SYSTEM DOES NOT HAVE ADEQUATE EXPOSURE DIVERSITY. ---

System is on N, E, S, W rosette.

Peak load exceeds 12-hour average load by 50.7%.

AED Excursion (amount by which peak exceeds 1.3 x average): 43 Btuh

Definition: A system has adequate exposure diversity if the peak-hour glass load for the entire conditioned space does not exceed the average glass load for the entire conditioned space by more than 30 percent.

(System Concept Warning for excursion equal to or exceeding 1.5 x baseline) This application has glass areas that produced large heat gains for part of the day. Variable air volume devices are required to overcome large spikes in solar gain for one or more rooms. Install a zoned system or provide zone control (individual, motorized, thermostatically controlled dampers) for problem rooms. Single speed equipment may not be suitable for the application.



Total Building Summary Loads

| Component Description | Area Quan | Sen Loss | Lat Gain | Sen Gain | Total Gain |
|--|-----------|----------|----------|----------|------------|
| Triple- shg: Glazing-south windows, u-value 0.2, SHGC 0.5 | 178.7 | 2,465 | 0 | 3,412 | 3,412 |
| Triple-Block: Glazing-My first example custom glass, u-value 0.18, SHGC 0.25 | 167 | 2,043 | 0 | 2,472 | 2,472 |
| Marvin-LowSHGC: Glazing-My first example custom glass, u-value 0.3, SHGC 0.18 | 3.9 | 81 | 0 | 29 | 29 |
| Masonite 1/4 Lite: Door-Masonite entry door with 1/4 lite | 20.1 | 319 | 0 | 111 | 111 |
| 11P: Door-Metal - Polyurethane Core | 20.1 | 286 | 0 | 140 | 140 |
| DbI Wall-12": Wall-Frame, , My first example custom wall | 2060.3 | 3,383 | 0 | 1,082 | 1,082 |
| 12F-5sw: Wall-Frame, R-21 insulation in 2 x 6 stud cavity, R-5 board insulation, siding finish, wood studs | 115.2 | 282 | 0 | 58 | 58 |
| Cellulose R60: Roof/Ceiling-Under Attic with Insulation on Attic Floor (also use for Knee Walls and Partition Ceilings), Custom, R60 cellulose | 1454.6 | 1,675 | 0 | 1,188 | 1,188 |
| 22B-15pl: Floor-Slab on grade, Vertical board insulation covers slab edge and extends straight down to 3' below grade, any floor cover, R-15 insulation, passive, light dry soil | 32 | 393 | 0 | 0 | 0 |
| 22D-15pl: Floor-Slab on grade, Vertical board insulation covers slab edge, turns under slab and extends 4' horizontally, any floor cover, R-15 insulation, passive, light dry soil | 153 | 1,773 | 0 | 0 | 0 |
| Subtotals for structure: | | 12,700 | 0 | 8,492 | 8,492 |
| People: | 12 | | 2,400 | 3,000 | 5,400 |
| Equipment: | | | 0 | 3,400 | 3,400 |
| Lighting: | 0 | | | 0 | 0 |
| Ductwork: | | 0 | 0 | 0 | 0 |
| Infiltration: Winter CFM: 10, Summer CFM: 3 | | 556 | 65 | 48 | 113 |
| Ventilation: Winter CFM: 89, Summer CFM: 89 | | 1,338 | 1,685 | 252 | 1,937 |
| Blower Heat Gain, 200 watts: | | 0 | 0 | 682 | 682 |
| AED Excursion: | | 0 | 0 | 1,676 | 1,676 |
| Total Building Load Totals: | | 14,594 | 4,150 | 17,551 | 21,701 |

Check Figures

| | | | |
|------------------------------|--------|---------------------|-------|
| Total Building Supply CFM: | 794 | CFM Per Square ft.: | 0.382 |
| Square ft. of Room Area: | 2,077 | Square ft. Per Ton: | 1,149 |
| Volume (ft³) of Cond. Space: | 17,612 | | |

Building Loads



| | | |
|---|-------------|--|
| Total Heating Required Including Ventilation Air: | 14,594 Btuh | 14.594 MBH |
| Total Sensible Gain: | 17,551 Btuh | 81 % |
| Total Latent Gain: | 4,150 Btuh | 19 % |
| Total Cooling Required Including Ventilation Air: | 21,701 Btuh | 1.81 Tons (Based On Sensible + Latent) |

Notes

Rhvac is an ACCA approved Manual J and Manual D computer program.
Calculations are performed per ACCA Manual J 8th Edition, Version 2, and ACCA Manual D.
All computed results are estimates as building use and weather may vary.
Be sure to select a unit that meets both sensible and latent loads.



Building Pie Chart





Building Bar Graph

