

Project Name : 4th Attempt

System : 1 Zone :2

Harrodsburg, KY, United States

LEXINGTON, BLUEGRASS AP, KENTUCKY

Summer Outdoor F:	89.0	Summer Indoor F:	75	Design Grains:	38	Daily Range:	MEDIUM
Winter Outdoor F:	13.0	Winter Indoor F:	70	Cooling RH:	50%	Elevation (Ft):	988

AED Excursion

7.4%

Internal

21.3%

Infiltration

3.6%

Ceiling

20%

Windows

36.3%

Above Grade Walls

11.5%

Cooling Loads

Name	Area	Sensible	Latent
Windows & Glass Doors	197	1,980	0
Skylights	0	0	0
Doors	0	0	0
Above Grade Walls	1,404	627	0
Floors	0	0	0
Ceiling	1,512	1,089	0
Ventilation	0	0	0
Infiltration	0	195	0
Internal	0	1,161	0
Duct	0	0	0
Blower Heat	0	0	0
AED Excursion	0	404	0

Total	3,113	5,455	0
--------------	-------	-------	---

Infiltration

16.3%

Ceiling

15.9%

Above Grade Walls

34.5%

Windows


33.3%

Heating Loads

Name	Area	Heat Loss
Windows & Glass Doors	197	3,256
Skylights	0	0
Doors	0	0
Above Grade Walls	1,404	3,371
Below Grade Walls	0	0
Ceiling	1,512	1,551
Ventilation	0	0
Infiltration	0	1,590
Internal	0	0
Floors	0	0
Duct	0	0
Humidification	0	0
Hot Water Piping	0	0

Total	3,113	9,769
--------------	-------	-------

Warning: This application has glass areas that produced relatively large cooling loads for part of the day. Variable air volume devices may be required to overcome spikes in solar load for one or more rooms. A zoned system may be required, or some rooms may require zone control (provided by individual, motorized, thermostatically controlled dampers)

AED Graph**Approved ACCA MJ8 Calculations**

Calculations are based on the ACCA Manual J 8th Edition and are approved by ACCA. All computed calculations are estimates on building use, weather data, and inputted values such as R-Values, window types, duct loss, etc. Equipment selections should meet both the latent and sensible gain as well as building heat loss. See Cool Calc Manual S Report for equipment sizing verification.