

dining room (closest to air handler) kitchen (almost closest to air handler) hallway (very far from air handler)

supply	return	outside		supply	return	outside		supply	return	outside
stage 1										
90	70	42		89	70	42		95	71	42
92	71	44		96	72	44		88	69	44
89	71	46		95	70	46		96	71	46
100	75	50		103	76	50		103	76	50
stage 2										
83	70	16		85	70	16		84	70	16
stage 2 after defrost										
88	69	30		91	68	30		88	68	30
defrost										
94	71	30		94	72	30		63	68	30
86	68	30		89	68	30		64	65	30
stage 2 with supplemental heat										
106	68	9		112	70	9		88	68	9