Hanaway HVAC Load Calculations

for

Susan Hanaway 234 E. Biddle Street 19380

Prepared By:

Dan Lippin Oliver HVAC 101 Waverly Avenue Morton, Pa. 19070 610-544-9920 Monday, October 24, 2016

Rhvac is an ACCA approved Manual J and Manual D computer program.
Calculations are performed per ACCA Manual J 8th Edition, Version 2, and ACCA Manual D.

Rhvac - Residential & Light Commercial HVAC Loads

Oliver Heating and Cooling Morton, PA 19070-1913



Elite Software Development, Inc.

Hanaway Page 2

Project Report

General Project Information

Project Title: Hanaway
Designed By: Dan Lippin
Project Date: 10/24/16

Project Comment:

Client Name: Susan Hanaway
Client Address: 234 E. Biddle Street

Client City: 19380
Client Fax: None
Company Name: Oliver I

Company Name: Oliver HVAC Company Representative: Dan Lippin

Company Address: 101 Waverly Avenue Company City: Morton, Pa. 19070 Company Phone: 610-544-9920

Company Comment:

Design Data

Reference City: Philadelphia AP, Pennsylvania

Building Orientation: Front door faces North

Daily Temperature Range: Medium
Latitude: 39 Degrees
Elevation: 5 ft.
Altitude Factor: 1.000

| | Outdoor | Outdoor | Outdoor | Indoor | Indoor | Grains |
|---------|-----------------|----------|---------|---------|----------|-------------------|
| | <u>Dry Bulb</u> | Wet Bulb | Rel.Hum | Rel.Hum | Dry Bulb | Difference |
| Winter: | 15 | 14 | n/a | n/a | 70 | n/a |
| Summer: | 93 | 74 | 41% | 50% | 70 | 41 |

Check Figures

Total Building Supply CFM: 2,253 CFM Per Square ft.: 0.793
Square ft. of Room Area: 2,841 Square ft. Per Ton: 574
Volume (ft³) of Cond. Space: 23,924

Building Loads

Total Heating Required Including Ventilation Air: 94,194 Btuh 94.194 MBH Total Sensible Gain: 49,568 Btuh 83 % Total Latent Gain: 9,826 Btuh 17 %

Total Cooling Required Including Ventilation Air: 59,393 Btuh 4.95 Tons (Based On Sensible + Latent)

Notes

Rhvac is an ACCA approved Manual J and Manual D computer program.

Calculations are performed per ACCA Manual J 8th Edition, Version 2, and ACCA Manual D.

All computed results are estimates as building use and weather may vary.

Be sure to select a unit that meets both sensible and latent loads according to the manufacturer's performance data at your design conditions.



Elite Software Development, Inc.

Hanaway Page 3

Total Building Summary Loads

| Total Dallaling Carrillary Loads | | | | | |
|--|------|--------|-------|--------|--------|
| Component | Area | Sen | Lat | Sen | Total |
| Description | Quan | Loss | Gain | Gain | Gain |
| C-cw: Glazing-Single pane window with storm, clear, wood frame, white or reflective color drapes with tight weave with 65% coverage, u-value 0.57, SHGC 0.56 | 192 | 6,019 | 0 | 5,506 | 5,506 |
| C-ca: Glazing-Single pane window with storm, clear, wood with metal clad frame, u-value 0.57, SHGC 0.56 | 212 | 6,646 | 0 | 7,516 | 7,516 |
| 1D: Door-Wood - Solid Core | 42 | 900 | 0 | 556 | 556 |
| 2A-2bw: Wall-Frame, no insulation in stud cavity, R-2 board insulation, brick finish, wood studs | 2911 | 31,062 | 0 | 14,345 | 14,345 |
| I6CR-11: Roof/Ceiling-Under Attic with Insulation on Attic Floor (also use for Knee Walls and Partition Ceilings), Vented Attic with Radiant Barrier, Dark Asphalt Shingles or Dark Metal, Tar and Gravel or Membrane, R-11 insulation | 216 | 962 | 0 | 840 | 840 |
| 6A-30: Roof/Ceiling-Under Attic with Insulation on Attic Floor (also use for Knee Walls and Partition Ceilings), Unvented Attic, No Radiant Barrier, Any Roofing Material, Any Roof Color, R-30 insulation | 770 | 1,355 | 0 | 1,922 | 1,922 |
| 9A-2p: Floor-Over enclosed unconditioned crawl space, No insulation on exposed walls, sealed or vented space, passive, R-2 or R-3 board | 1196 | 6,272 | 0 | 2,623 | 2,623 |
| Subtotals for structure: | | 53,216 | 0 | 33,308 | 33,308 |
| People: | 6 | | 1,200 | 1,380 | 2,580 |
| Equipment: | | | 1,000 | 500 | 1,500 |
| Lighting: | 0 | | | 0 | 0 |
| Ductwork: | | 0 | 2,701 | 9,942 | 12,642 |
| Infiltration: Winter CFM: 372, Summer CFM: 175 | | 22,498 | 4,925 | 4,438 | 9,363 |
| Ventilation: Winter CFM: 0, Summer CFM: 0 | | 0 | 0 | 0 | 0 |
| Hot Water Piping, 80 ft. Total: | | 18,480 | 0 | 0 | 0 |
| Total Building Load Totals: | | 94,194 | 9,826 | 49,568 | 59,393 |
| Obselv Figures | | | | | |

| C | <u>hec</u> | <u>k F</u> | ig | ur | es |
|---|------------|------------|----|----|----|
| | | | | | |

| Total Building Supply CFM: | 2,253 | CFM Per Square ft.: | 0.793 |
|------------------------------|--------|---------------------|-------|
| Square ft. of Room Area: | 2,841 | Square ft. Per Ton: | 574 |
| Volume (ft³) of Cond. Space: | 23,924 | | |

Building Loads

| Total Heating Required Including Ventilation Air: | 94,194 | Btuh | 94.194 | MBH |
|---|--------|------|--------|-----------------------------------|
| Total Sensible Gain: | 49,568 | Btuh | 83 | % |
| Total Latent Gain: | 9,826 | Btuh | 17 | % |
| Total Cooling Required Including Ventilation Air: | 59,393 | Btuh | 4.95 | Tons (Based On Sensible + Latent) |

Notes

Rhvac is an ACCA approved Manual J and Manual D computer program.

Calculations are performed per ACCA Manual J 8th Edition, Version 2, and ACCA Manual D.

All computed results are estimates as building use and weather may vary.

Be sure to select a unit that meets both sensible and latent loads according to the manufacturer's performance data at your design conditions.