

Room Name	Floor Level	Conditioned Space	Load Calculation
Basement Bath	-1	Cooled: false	Sensible BTU: 0
		Heated: true	Latent BTU: 0
		Zone:	Heating BTU: 799
Basement Bd1	-1	Cooled: false	Sensible BTU: 0
		Heated: true	Latent BTU: 0
		Zone:	Heating BTU: 2,496
Basement BD2	-1	Cooled: false	Sensible BTU: 0
		Heated: true	Latent BTU: 0
		Zone:	Heating BTU: 2,197
Basement Hall	-1	Cooled: false	Sensible BTU: 0
		Heated: true	Latent BTU: 0
		Zone:	Heating BTU: 0
Garage	-1	Cooled: false	Sensible BTU: 0
		Heated: true	Latent BTU: 0
		Zone:	Heating BTU: 3,856
Bed 1 upstairs	1	Cooled: true	Sensible BTU: 1,437
		Heated: true	Latent BTU: 11
		Zone:	Heating BTU: 2,295
Bed 2 Upstairs	1	Cooled: true	Sensible BTU: 1,477
		Heated: true	Latent BTU: 10
		Zone:	Heating BTU: 2,150
first bath	1	Cooled: true	Sensible BTU: 144
		Heated: true	Latent BTU: 2
		Zone:	Heating BTU: 329
KitLivDin	1	Cooled: true	Sensible BTU: 4,769
		Heated: true	Latent BTU: 385
		Zone:	Heating BTU: 4,989
Load Calculation			
Heating BTU	Cooling BTU	SHR	CFM
19,110	10,013	0.939	474