

### Project Information

Project #: 45  
Name: 54  
Location: tinmouth

Notes:

#### Outdoor Conditions

Location: (User Specified)  
Tinmouth, Vermont  
Elevation: 1400'  
Latitude: 43.52  
Dry Bulb: -3.0 °F  
Daily Range:  
Wet Bulb: 68.6 °F

#### Infiltration

Method: Maximum ACH50  
Stories: 1  
Exposure Category: One or Two Exposures  
Wind Shielding: 4 - Mostly Shielded Exposures  
Max ACH50: 0.80  
Net Air Changes (H/C): 0.07/0.03  
Net Flow (H/C): 17 cfm/7 cfm

#### Indoor Conditions

Room Temp: 68 °F  
Design Temp Diff: 71.0 °F  
Humidity: 35  
Moisture Diff (Grains):

#### Ventilation

Num Occupants: 4  
Type: Heating  
ACH: 0.26  
Outside Air: 60 cfm  
Sensible Eff: 50 %

#### Floorplan/Levels

Basement: 981 ft<sup>2</sup>  
Main Floor: 992 ft<sup>2</sup>  
Total Heated Area: 1,973 ft<sup>2</sup>  
Total Cooled Area: 1,973 ft<sup>2</sup>

**Total Heating: 18,499 Btu/hr**  
**Total Sensible: 12,330 Btu/hr**  
**Total Latent: 1,587 Btu/hr**

#### Load Breakdown


Name	Heating	Sensible	Latent
Windows*	8,182	7,797	
Skylights*	0	0	
Doors	398	96	
Walls	3,216	320	
Below Grade Walls	669		
Ceilings	1,264	555	
Floors	1,249	1	
Infiltration	1,280	45	81
Internal		3,320	800
Other	0		
Duct Loads	0	0	0
Ventilation	2,242	196	706
Humidification	0		
Piping Load	0		
Radiant Back Loss	0		
Blower Heat		0	
AED*		0	
<b>Total</b>	<b>18,499</b>	<b>12,330</b>	<b>1,587</b>
<b>Total Area</b>	<b>1,973 ft<sup>2</sup></b>	<b>1,973 ft<sup>2</sup></b>	

\*Average Load Procedure


Heating ΔT<sup>1</sup>: 70.0  
Cooling ΔT<sup>1</sup>: 18.0  
Est. Heating CFM<sup>2</sup>: 0  
Est. Cooling CFM<sup>2</sup>: 640

JSHR: 0.89  
MJ8 Tons: 1.16  
SqFt/Ton: 1701  
CFM/SqFt: 0.32


#### Heating Load Breakdown



#### Sensible Load Breakdown



#### Fenestration Load vs Hour of Day - Block Load (Summer)



Average Load: 8,731 Btu/hr  
Excursion Limit: 11,350 Btu/hr

Peak Load: 9,875 Btu/hr  
AED Load: 0 Btu/hr

(1) ΔT: Difference between supply air and return air (2) Estimated air flow based on specified supply air ΔT

Length = ft Area = ft<sup>2</sup> Temperature = °F Flowrate = USGPM Air Flow = cfm Heat Loss = Btu/hr  
Unit Heat Loss = Btu/hr-ft<sup>2</sup> Rv = hr-ft<sup>2</sup>-°F/btu Head Loss = ft water RH = Radiant Floor Heating  
BB = Baseboard FA = Forced Air OTH = Other Heating SM = Snowmelt N = Not Heated

---

## Warnings

The sensible load for some rooms peak during late fall or early winter. This behavior is caused by glass that faces South East, South or South West. Room temperature may be difficult to control if zoning is not provided.

The ventilation rate for the building is less than the Manual J recommended value of 82 CFM.

## Disclaimers

With the permission of the Air Conditioning Contractors of America ("ACCA"), material is reproduced from Manual J Residential Load Calculation (8th Edition) which is copyrighted by ACCA. The program and data are provided "as is" without warranty of any kind either expressed or implied. The entire risk as the quality and performance of the program and data is with you. In no event will ACCA be liable to you for any damages, including without limitation any lost profits, lost savings, or other incidental or consequential damages arising out of the use or inability to use this program or the data. © 2015 Air Conditioning Contractors of America. All Rights Reserved. www.acca.org

ACCA, Manual J and Powered by ACCA Manual J are registered trademarks of the Air Conditioning Contractors of America. All rights reserved.

Cold weather humidification, or some lifestyles that produce excessive moisture, may cause condensation to occur if the absolute humidity of the indoor air is too high for the momentary circumstances. Condensation can occur on surfaces or concealed within the structure, and can lead to mold, mildew, frost damage, and moisture damage. The software does not perform calculations for the estimation or detection of possible condensation problems, and it is the designers (i.e. software users) responsibility to do so independently if required. For guidance and additional cautions refer to ACCA Manual J 8th Edition, including Section 1-11 and Section 27.

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.

---

(1)  $\Delta T$ : Difference between supply air and return air (2) Estimated air flow based on specified supply air  $\Delta T$

Length = ft Area = ft<sup>2</sup> Temperature = °F Flowrate = USGPM Air Flow = cfm Heat Loss = Btu/hr  
Unit Heat Loss = Btu/hr·ft<sup>2</sup> Rv = hr·ft<sup>2</sup>·°F/btu Head Loss = ft water RH = Radiant Floor Heating  
BB = Baseboard FA = Forced Air OTH = Other Heating SM = Snowmelt N = Not Heated

Created Using HeatCAD 2019 (8/20/2019)  
Version:19.0.0280 R (Trial)