343

R702.3.4 Insulating concrete form walls. Foam plastics for insulating concrete form walls constructed in accordance with Sections R404.1.2 and R608 on the interior of *habitable spaces* shall be protected in accordance with Section R316.4. Use of adhesives in conjunction with mechanical fasteners is permitted. Adhesives used for interior and exterior finishes shall be compatible with the insulating form materials.

R702.3.5 Application. Supports and fasteners used to attach gypsum board and gypsum panel products shall com-

ply with Table R702.3.5. Gypsum sheathing shall be attached to exterior walls in accordance with Table R602.3(1). Gypsum board and gypsum panel products shall be applied at right angles or parallel to framing members. All edges and ends of gypsum board and gypsum panel products shall occur on the framing members, except those edges and ends that are perpendicular to the framing members. Interior gypsum board shall not be installed where it is directly exposed to the weather or to water.

THIOKALEOO OF		INNESS AND AFFEI				GYPSUM PANEL PRODUCTS	
THICKNESS OF GYPSUM BOARD OR GYPSUM PANEL PRODUCTS (inches)	APPLICATION	ORIENTATION OF GYPSUM BOARD OR GYPSUM PANEL PRODUCTS TO FRAMING	MAXIMUM SPACING OF FRAMING MEMBERS (inches o.c.)	MAXIMUM SPACING OF FASTENERS (inches)			
				Nails ^a	Screws ^b	SIZE OF NAILS FOR APPLICATION TO WOOD FRAMING [®]	
Application without adhesive							
3/8	Ceiling ^d	Perpendicular	16	7	12	13 gage, $1^{1}{}'_{4}^{"}$ long, $1^{9}{}'_{6}^{"}$ head; 0.098" diameter, $1^{1}{}'_{4}^{"}$ long, annular-ringed; or 4d cooler nail, 0.080" diameter, $1^{3}{}'_{8}^{"}$ long, $7{}_{32}^{"}$ head.	
	Wall	Either direction	16	8	16		
1/ ₂	Ceiling	Either direction	16	7	12	13 gage, $1^{3}/_{8}" \log_{10} 1^{9}/_{64}"$ head; 0.098" diameter, $1^{1}/_{4}" \log_{10}$ annular-ringed; 5d cooler nail, 0.086" diameter, $1^{5}/_{8}" \log_{10} 1^{5}/_{64}"$ head; or gypsum board nail, 0.086" diameter, $1^{5}/_{8}" \log_{10} 9/_{32}"$ head.	
	Ceiling ^d	Perpendicular	24	7	12		
	Wall	Either direction	24	8	12		
	Wall	Either direction	16	8	16		
5/8	Ceiling	Either direction	16	7	12	13 gage, $1^{5'_8}$ " long, $1^{9'_{6'}}$ head; 0.098" diameter, $1^{3'_8}$ " long, annular-ringed; 6d cooler nail, 0.092" diameter, $1^{7'_8}$ " long, $1'_4$ " head; or gypsum board nail, 0.0915" diameter, $1^{7'_8}$ " long, $1^{9'_64}$ " head.	
	Ceiling	Perpendicular	24	7	12		
	Type X at garage ceiling beneath habitable rooms	Perpendicular	24	6	6	$1^{7}/_{8}$ " long 6d coated nails or equivalent drywall screws. Screws shall comply with Section R702.3.5.1	
	Wall	Either direction	24	8	12	13 gage, $1^{5}/_{8}''$ long, $1^{9}/_{64}''$ head; 0.098'' diameter, $1^{3}/_{8}''$ long, annular-ringed; 6d cooler nail, 0.092'' diameter, $1^{7}/_{8}''$ long, $1^{1}/_{4}''$ head; or gypsum board nail, 0.0915'' diameter, $1^{7}/_{8}''$ long, $1^{9}/_{64}''$ head.	
	Wall	Either direction	16	8	16		
			Application	with adhesiv	/e		
3/8	Ceiling ^d	Perpendicular	16	16	16	Same as above for $\frac{3}{8}''$ gypsum board and gypsum panel products.	
	Wall	Either direction	16	16	24		
¹ / ₂ or ⁵ / ₈	Ceiling	Either direction	16	16	16	Same as above for $\frac{1}{2}$ and $\frac{5}{8}$ gypsum board and gypsum panel products, respectively.	
	Ceiling ^d	Perpendicular	24	12	16		
	Wall	Either direction	24	16	24		
Two ³ / ₈ layers	Ceiling	Perpendicular	16	16	16	Base ply nailed as above for $1/2''$ gypsum board and gypsum panel products; face ply installed with adhesive.	
	Wall	Either direction	24	24	24		

TABLE R702.3.5							
MINIMUM THICKNESS AND APPLICATION OF GYPSUM BOARD AND GYPSUM PANEL PRODUCTS							

For SI: 1 inch = 25.4 mm.

a. For application without adhesive, a pair of nails spaced not less than 2 inches apart or more than 2¹/₂ inches apart shall be permitted to be used with the pair of nails spaced 12 inches on center.

b. Screws shall be in accordance with Section R702.3.6. Screws for attaching gypsum board or gypsum panel products to structural insulated panels shall penetrate the wood structural panel facing not less than $^{7}/_{16}$ inch.

c. Where cold-formed steel framing is used with a clinching design to receive nails by two edges of metal, the nails shall be not less than $\frac{5}{8}$ inch longer than the gypsum board or gypsum panel product thickness and shall have ringed shanks. Where the cold-formed steel framing has a nailing groove formed to receive the nails, the nails shall have barbed shanks or be 5d, $13^{1/2}$ gage, $1^{5/8}$ inches long, $\frac{15}{64}$ -inch head for $\frac{1}{2}$ -inch gypsum board or gypsum panel product; and 6d, 13 gage, $1^{7/8}$ inches long, $\frac{15}{64}$ -inch head for $\frac{5}{8}$ -inch gypsum board or gypsum panel product.

d. Three-eighths-inch-thick single-ply gypsum board or gypsum panel product shall not be used on a ceiling where a water-based texture finish is to be applied, or where it will be required to support insulation above a ceiling. On ceiling applications to receive a water-based texture material, either hand or spray applied, the gypsum board or gypsum panel product shall be applied perpendicular to framing. Where applying a water-based texture material, the minimum gypsum board thickness shall be increased from $\frac{3}{4}$ inch to $\frac{1}{2}$ inch for 16-inch on center framing, and from $\frac{1}{2}$ inch to $\frac{5}{8}$ inch for 24-inch on center framing or $\frac{1}{2}$ -inch sag-resistant gypsum ceiling board shall be used.

2015 INTERNATIONAL RESIDENTIAL CODE®

