

Seasonal Energy Use (01 October – 31 May)

| | | |
|------------------------------------|----------|--------|
| Heat Pump Water Heater | | |
| 2018 - 2019 | 308.4 | kWh |
| 2017 - 2018 | 304.5 | kWh |
| 2016 - 2017 | 362.2 | kWh |
| Upper Level Heat Pump | | |
| 2018 - 2019 | 3,177.5 | kWh |
| 2017 - 2018 | 2,695.2 | kWh |
| 2016 - 2017 | 2,866.2 | kWh |
| Lower Level Heat Pump | | |
| 2018 - 2019 | 2,760.7 | kWh |
| 2017 - 2018 | 2,444.8 | kWh |
| 2016 - 2017 | 2,308.9 | kWh |
| Combined Heat Pump | | |
| 2018 - 2019 | 5,938.2 | kWh |
| 2017 - 2018 | 5,140.0 | kWh |
| 2016 - 2017 | 5,175.1 | kWh |
| Miscellaneous Loads | | |
| 2018 - 2019 | 1,574.1 | kWh |
| 2017 - 2018 | 1,654.5 | kWh |
| 2016 - 2017 | 1,906.9 | kWh |
| Total Load | | |
| 2018 - 2019 | 7,820.7 | kWh |
| 2017 - 2018 | 7,099.1 | kWh |
| 2016 - 2017 | 7,444.3 | kWh |
| Fuel Oil Consumption | | |
| 2018 - 2019 | 195.8 | litres |
| 2017 - 2018 | 203.0 | litres |
| 2016 - 2017 | 161.0 | litres |
| Space Heating Demand | | |
| 2018 - 2019 | 20,404.6 | kWh |
| 2017 - 2018 | 19,235.7 | kWh |
| 2016 - 2017 | 18,566.7 | kWh |
| Average Outdoor Temperature | | |
| 2018 - 2019 | 2.2 | °C |
| 2017 - 2018 | 4.2 | °C |
| 2016 - 2017 | 3.5 | °C |
| Average Indoor Temperature | | |
| 2018 - 2019 | 18.2 | °C |
| 2017 - 2018 | 19.3 | °C |
| 2016 - 2017 | 18.0 | °C |

Space Heating Demand — 31 May, 2019



Seasonal Particulars to Date (Year over Year)

