

16 — 17	Average Temp °C	Low °C	High °C	Hours < -15°C	Space Heating Demand (kWh)			Heat Pumps (kWh)		Energy Consumption (kWh)			
					Daily Min.	Daily Max.	Total	Main Floor	Lower Level	Heat Pumps	DHW	Misc.	Total Load
October	10.5	-0.4	21.4	0	0	66	819	0	40	40	50	239	329
November	5.6	-1.5	13.2	0	16	79	1,641	183	136	320	44	233	597
December	-1.3	-15.7	10.2	9	51	181	3,077	590	290	880	46	277	1,203
January	-1.3	-18	8.6	12	52	174	3,075	690	296	987	44	240	1,271
February	-2.2	-15.5	9.0	2	56	161	2,944	543	556	1,099	32	240	1,371
March	-1.6	-16.8	9.4	12	54	169	3,129	589	653	1,242	43	264	1,548
April	6.4	-4.5	20.4	0	8	87	1,501	226	231	457	50	209	716
May	11.4	-2.6	31.4	0	2	55	736	45	107	151	53	205	409
Average / Max.	3.4	-18.0	31.4	35	0	181	16,923	2,866	2,309	5,175	362	1,907	7,444

■ Upper Heat Pump
■ Lower Heat Pump
■ Domestic Hot Water
■ All Other Loads

17 — 18	Average Temp °C	Low °C	High °C	Hours < -15°C	Space Heating Demand (kWh)			Heat Pumps (kWh)		Energy Consumption (kWh)			
					Daily Min.	Daily Max.	Total	Main Floor	Lower Level	Heat Pumps	DHW	Misc.	Total Load
October	12.4	2.1	22.3	0	0	51	580	103	32	135	44	179	359
November	5.3	-5.6	19.2	0	0	108	1,730	337	227	564	40	231	835
December	-0.9	-13.7	12.0	0	31	171	2,985	555	481	1,036	35	228	1,299
January	-2.7	-15.3	13.9	2	13	175	3,361	695	568	1,263	37	279	1,579
February	0.3	-13.2	10.2	0	50	164	2,493	327	289	616	27	205	848
March	1.5	-9.0	11.5	0	53	123	2,512	403	494	897	35	222	1,154
April	5.2	-6.0	17.8	0	11	98	1,739	259	298	557	39	207	803
May	12.2	2.4	28.4	0	6	43	624	17	54	71	48	189	308
Average / Max.	4.2	-15.3	28.4	2	0	175	16,024	2,695	2,444	5,139	305	1,740	7,185

■ Upper Heat Pump
■ Lower Heat Pump
■ Domestic Hot Water
■ All Other Loads

18 — 19	Average Temp °C	Low °C	High °C	Hours < -15°C	Space Heating Demand (kWh)			Heat Pumps (kWh)		Energy Consumption (kWh)			
					Daily Min.	Daily Max.	Total	Main Floor	Lower Level	Heat Pumps	DHW	Misc.	Total Load
October	9.2	-2.6	18.9	0	0	78	1,163	115	92	207	45	192	444
November	3.4	-10.1	18.3	0	6	137	2,378	386	268	654	46	184	884
December	-2.4	-12.2	13.1	0	53	144	3,518	633	450	1,083	44	169	1,296
January	-3.0	-14.4	10.4	0	74	157	3,693	696	440	1,137	23	169	1,328
February	-4.5	-15.1	6.7	1	85	160	3,484	704	513	1,218	27	151	1,396
March	-0.4	-15.7	13.6	2	67	156	3,247	563	457	1,020	32	176	1,228
April	5.6	-3.2	17.4	0	22	93	1,702	79	320	399	41	287	727
May	9.1	0.2	22.1	0	24	58	1,221	0	220	220	50	247	517
Average / Max.	2.1	-15.7	22.1	3	0	160	20,405	3,177	2,761	5,938	308	1,574	7,821

■ Upper Heat Pump
■ Lower Heat Pump
■ Domestic Hot Water
■ All Other Loads