

Room Data and Loads hide from printout

Room Name	Suggested Ducts	Actual Ducts	Duct Size	CFM/Duct	Actual CFM Measured	Floor Area	Ext. Length	Height Override	Uncond Ceiling	Uncond Floor	Heating Load	Cooling Load
Touch Down area	1		3	29		54	15.0	8.0	0 %	0 %	1,617	672
Washroom			3	0		25	0.0	8.0	0 %	0 %	46	48
Utility & Laundry	1		3	50		231	33.4	9.0	0 %	0 %	3,038	853
Flex Room	1		3	23		191	14.0	9.0	0 %	0 %	1,549	709
Kitchen			3	0		238	0.0	9.0	0 %	0 %	439	461
Dining Room	2		3	48		51	24.8	9.0	0 %	0 %	2,851	2,263
Living Room	2		3	49		188	27.4	9.0	0 %	0 %	3,300	2,550
Stairs	1		3	30		82	6.3	19.0	0 %	0 %	1,006	837
Entrance	1		3	37		91	20.0	9.0	0 %	0 %	2,086	681
Hallway	1		3	20		28	0.0	9.0	0 %	0 %	327	511
Ensuite	1		3	26		75	16.3	8.0	0 %	0 %	1,465	539
Walk-in Closet	1		3	9		59	6.0	8.0	0 %	0 %	553	160
Master Bedroom	1		3	49		243	24.8	8.7	0 %	0 %	2,714	1,562
Bedroom 2 (G)	1		3	46		196	28.0	8.0	0 %	0 %	2,743	1,286
Bedroom 3 (A)	1		3	44		190	27.6	8.0	0 %	0 %	2,617	1,001
Bathroom 2	1		3	17		70	10.7	8.0	0 %	0 %	1,007	360
Office	1		3	34		88	22.0	8.0	0 %	0 %	1,927	566
Total	17	0				2,100					29,284	15,061