

CANNOT VERIFY IF EXISTING STUD WALL  
INCLUDES INSULATION OR A VAPOUR BARRIER

APPROX 1-1/2" BETWEEN CONCRETE AND  
BLOCK WALLS

NEW SIDING ON  
FURRING AND 1" EPS  
INSULATION LAYER  
INSTALLED OVER EXISTING  
SIDING

EXISTING RIM JOIST  
AND FLOOR FRAMING  
(WOOD)

CONDENSATION OBSERVED  
IN BLUE ZONE AFTER NEW  
FIBERGLASS INSULATION WAS  
REMOVED FROM STUD CAVITY

CEMENT PATCHING ON  
EXISTING CONC. FOUNDATION

NEW WATERPROOF AND  
DRAINAGE MEMBRANES  
BEHIND 1" CLOSED-CELL  
EPS INSULATION

NEW STUD WALLS INSTALLED  
1" FROM BLOCK WALL

3/4" PLASTER/GYPSUM DIRECTLY  
ON BLOCK WALL (EXISTING)

EXISTING CONCRETE BLOCK  
WALL

NEW PERIMETER  
DRAINAGE SYSTEM

NEW SELF-LEVELLING CONC.  
LAYER W/ SPRAY FOAM EDGE  
AT WOOD PARTITIONS

EXISTING CONCRETE SLAB  
(LIKELY WITH NO VAPOUR  
BARRIER)

NEW CAPILLARY BREAK  
(ETHAFOAM)

