

		Target	Initial Reading	Delta	Diff.	Adjusted Reading	Delta	Diff.	
Basement	Mech	45	155	110	244%	29.4	-15.6	-35%	Closer
Basement	Main SE	40	29.4	-10.6	-27%	43	3	8%	Closer
Basement	Main SW	40	70	30	75%	51	11	28%	Closer
Basement	Office	50	117.6	67.6	135%	43	-7	-14%	Closer
Main	Kitchen N	115	220	105	91%	108	-7	-6%	Closer
Main	Kitchen S	115	220	105	91%	100	-15	-13%	Closer
Main	LR SE	70	61	-9	-13%	68	-2	-3%	Closer
Main	LR SSE	75	58.29	-16.71	-22%	47	-28	-37%	Worse
Main	LR SSW	100	60	-40	-40%	68	-32	-32%	Closer
Main	LR SW	100	53	-47	-47%	65	-35	-35%	Closer
Main	Mudroom	45	54	9	20%	30	-15	-33%	Worse
Main	Laundry	45	58	13	29%	38	-7	-16%	Closer
Main	Sauna Landing	40	52.2	12.2	31%	36	-4	-10%	Closer
Main	Bath	30	56	26	87%	29	-1	-3%	Closer
Main	Office SE	50	64	14	28%	24	-26	-52%	Worse
Main	Office SW	60	63	3	5%	48	-12	-20%	Worse
2nd	Bath	35	17.4	-17.6	-50%	35	0	0%	Closer
2nd	Bed SW	60	24	-36	-60%	55	-5	-8%	Closer
2nd	Bed SE	95	21	-74	-78%	63	-32	-34%	Closer
		1210	1453.89	243.89	26%	980.4	-229.6	-17%	