

Project Information

Project #: L211
 Name: Matthew Holmes
 Location: 10403, Y1A7A1, Whitehorse, Yukon, Canada

Notes:

Outdoor Conditions

Location: Whitehorse, Yukon Territory
 Latitude: 61
 Soil Temp: 37.4 °F
 Heating Design Temp: -41.8 °F
 Cooling Design Temp: 77.0 °F

Infiltration

See detailed load report for all settings
 Stories: Two
 Type: Detached
 Air Tightness: Custom - BDT values
 Heating Air Changes: 0.18 /hr
 Cooling Air Changes: 0.02 /hr

Floorplan/Levels

Ground Floor: 1,000 ft²
 Main Floor: 1,066 ft²
 Total Heated Area: 2,066 ft²
 Total Cooled Area: 2,131 ft²

Indoor Conditions

Heating
 Room Temp: 70 °F °F
 Design ΔT: 111.8 °F

Cooling
 Room Temp: 75 °F °F
 Design ΔT: 2.0 °F

Ventilation

Num Occupants: 2
Heating
 Air Changes: 0.28 /hr
 Flowrate: 100 cfm
 Effectiveness*: 0.6

Cooling
 Air Changes: 0.27 /hr
 Flowrate: 100 cfm
 Effectiveness*: 0.6

Total Heat Loss: 29,233 Btu/hr


Total Heat Gain: 10,103 Btu/hr

Latent Factor: 1.3


Load Breakdown

| Name | Heat Loss | Heat Gain |
|-----------------------------------|------------------|------------------|
| Windows | 6,231 | 4,013 |
| Doors | 386 | 0 |
| Skylights | 0 | 0 |
| Above Grade Walls | 6,133 | 98 |
| Exposed Floors | 0 | 0 |
| Foundation | 102 | 0 |
| Infiltration | 8,095 | 16 |
| Ceiling | 1,354 | 351 |
| Duct Loads | 0 | 0 |
| Ventilation | 4,801 | 86 |
| Internal Loads | 0 | 3,207 |
| Other Loads | 0 | 0 |
| External Floor Radiant Panel Loss | 2,131 | 0 |
| Internal Floor Radiant Panel Loss | 4,209 | 0 |
| Total Sensible | 29,233 | 7,772 |
| Latent Gain | 0 | 2,332 |
| Total Load | 29,233 | 10,103 |
| Total Area | 2,066 ft² | 2,131 ft² |

Heat Loss Breakdown



Heat Gain Breakdown



(*): Heating: apparent sensible effectiveness of the HRV; Cooling: adjusted total recovery efficiency of the HRV/ERV.

Calculations meet requirements of CSA F280-12 (R2021 Update 3)
 Length = ft Area = ft² Temperature = °F Flowrate = USGPM Air Flow = cfm Heat Loss = Btu/hr
 Unit Heat Loss = Btu/(hr·ft²) Rv = hr·ft²·°F/btu Head Loss = ft water RH = Radiant Floor Heating
 BB = Baseboard FA = Forced Air OTH = Other Heating SM = Snowmelt N = Not Heated

Disclaimers

With the permission of Canadian Standards Association, material is reproduced from CSA Standard, CSA F280-12 (Revision 2021 Update 3), Determining the Required Capacity of Residential Space Heating and Cooling Appliances which is copyrighted by Canadian Standards Association, 178 Rexdale Blvd., Toronto, Ontario, M9W 1R3, www.shopcsa.ca. While use of this material has been authorized, CSA shall not be responsible for the manner in which the information is presented, nor for any interpretations thereof.

Cold weather humidification, or some lifestyles that produce excessive moisture, may cause condensation to occur if the absolute humidity of the indoor air is too high for the momentary circumstances. Condensation can occur on surfaces or concealed within the structure, and can lead to mold, mildew, frost damage, and moisture damage. The software does not perform calculations for the estimation or detection of possible condensation problems, and it is the designers (i.e. software users) responsibility to do so independently if required.

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.

(* Heating: apparent sensible effectiveness of the HRV; Cooling: adjusted total recovery efficiency of the HRV/ERV.

Calculations meet requirements of CSA F280-12 (R2021 Update 3)

Length = ft Area = ft² Temperature = °F Flowrate = USGPM Air Flow = cfm Heat Loss = Btu/hr
Unit Heat Loss = Btu/(hr·ft²) Rv = hr·ft²·°F/btu Head Loss = ft water RH = Radiant Floor Heating
BB = Baseboard FA = Forced Air OTH = Other Heating SM = Snowmelt N = Not Heated

Created Using LoopCAD 2023 (2023-10-24)
Software Version:23.0.0180 R

See sections at end of report for important Notes, Assumptions and Disclaimers.



Load Details

CSA F280 Load Calculation

Project #:L211

October 03, 2023

Project Information

Project #: L211
 Name: Matthew Holmes
 Location: 10403, Y1A7A1, Whitehorse, Yukon, Canada

Notes:

CSA Load Details

Total Heating: 29,233 Btu/hr **Total Cooling: 10,103 Btu/hr** **Latent Factor: 1.3**

Outdoor Conditions

Location: Whitehorse, Yukon Territory
 Latitude: 61
 Soil Temp: 37.4 °F
 Heating Design Temp: -41.8 °F
 Cooling Design Temp: 77.0 °F

Indoor Conditions

| | Heating | Cooling |
|------------|----------|---------|
| Room Temp: | 70 °F | 75 °F |
| Design ΔT: | 111.8 °F | 2.0 °F |

Infiltration

Stories: Two
 Air Tightness: Custom - BDT values
 Building Site: Suburban, forest
 Walls Shielding: Very heavy
 Flue Shielding: Heavy
 Building Type/Foundation: Detached/ Full
 ELA Pressure: ELA @ 10 Pa
 ELA: 26 in²
 ACH 50 Pa: 0.70 /hr
 Flue Diameters: 4 in, 4 in
 Building Volume / Height: 22,093 ft³ / 24'-11"
 Heating Air Changes: 0.18 /hr
 Cooling Air Changes: 0.02 /hr

Ventilation

| | Heating | Cooling |
|-----------------|----------|----------|
| Air Changes: | 0.28 /hr | 0.27 /hr |
| Flowrate: | 100 cfm | 100 cfm |
| Effectiveness*: | 0.6 | 0.6 |

Floorplan/Levels

Calculations meet requirements of CSA F280-12 (R2021 Update 3)

(1) ΔT: Difference between supply air and return air (2) Estimated air flow based on specified supply air ΔT

(*) Heating: apparent sensible effectiveness of the HRV; Cooling: adjusted total recovery efficiency of the HRV/ERV.

Length = ft Area = ft² Temperature = °F Flowrate = USGPM Air Flow = cfm Heat Loss = Btu/hr Unit Heat Loss = Btu/(hr-ft²) Rv = hr-ft²-°F/btu
 Head Loss = ft water RH = Radiant Floor Heating BB = Baseboard FA = Forced Air OTH = Other Heating SM = Snowmelt N = Not Heated

Created Using LoopCAD 2023 (2023-10-24)

Version:23.0.0180 R

See end of report for important Notes and Disclaimers.

| | | | |
|--------------|-----------------------|--------------------|-----------------------|
| Ground Floor | 1,000 ft ² | Total Heated Area: | 2,066 ft ² |
| Main Floor | 1,066 ft ² | Total Cooled Area: | 2,131 ft ² |

Constructions

Doors

| Description | R-Value | Area | Heating | Cooling |
|---------------------------------------|---------|------|---------|---------|
| Insulated fiberglass—Polystyrene core | 4.83 | 17 | 386 | 0 |

Walls

| Description | R-Value | Area | Heating | Cooling |
|-------------|---------|-------|---------|---------|
| Wall | 48.0 | 2,805 | 6,133 | 98 |

Ceilings

| Description | R-Value | Area | Heating | Cooling |
|-------------|---------|-------|---------|---------|
| Ceiling | 88.0 | 1,066 | 1,354 | 351 |


Glazing

Windows

| Description | Exposure | R-Value | SHGC | Area | Heating | Cooling |
|-------------|----------|---------|------|------|---------|---------|
| Glass | E | 6.4 | 0.30 | 57 | 1,002 | 795 |
| Glass | S | 6.4 | 0.30 | 188 | 3,281 | 1,917 |
| Glass | W | 6.4 | 0.30 | 85 | 1,479 | 1,174 |
| Glass | N | 6.4 | 0.30 | 27 | 469 | 127 |

Foundations

| ID | Code | Description | Area | Heat Loss | Options |
|----|--------|-------------|-------|-----------|--|
| F0 | SCB_25 | Slab Floors | 1,066 | 2,233 | Slab Insulation: 20.0 hr·ft ² ·°F/btu |



F0

Description

- SCB_25
- concrete or soil (for crawl space) floor
 - bottom of slab fully insulated except under footing/foundation wall (ie. insulation starts 0.25 m from edge)
 - first storey is non-brick veneer or bricks thermally broken from concrete floor

Options

Slab Insulation: 20.0 hr·ft²·°F/btu

Duct Loads

Calculations meet requirements of CSA F280-12 (R2021 Update 3)

(1) ΔT: Difference between supply air and return air (2) Estimated air flow based on specified supply air ΔT

(*) Heating: apparent sensible effectiveness of the HRV; Cooling: adjusted total recovery efficiency of the HRV/ERV.

Length = ft Area = ft² Temperature = °F Flowrate = USGPM Air Flow = cfm Heat Loss = Btu/hr Unit Heat Loss = Btu/(hr·ft²) Rv = hr·ft²·°F/btu
 Head Loss = ft water RH = Radiant Floor Heating BB = Baseboard FA = Forced Air OTH = Other Heating SM = Snowmelt N = Not Heated

All ducts are in conditioned space.



Internal Loads

Occupants: 2
Total Internal Heat Gain: 10,103 Btu/hr

No rooms specified at peak cooling. Internal loads will be evenly distributed throughout the building.

Load Breakdown

| Name | Heat Loss | Heat Gain |
|-----------------------------------|-----------------------|-----------------------|
| Windows | 6,231 | 4,013 |
| Doors | 386 | 0 |
| Skylights | 0 | 0 |
| Above Grade Walls | 6,133 | 98 |
| Exposed Floors | 0 | 0 |
| Foundation | 102 | 0 |
| Infiltration | 8,095 | 16 |
| Ceiling | 1,354 | 351 |
| Duct Loads | 0 | 0 |
| Ventilation | 4,801 | 86 |
| Internal Loads | 0 | 3,207 |
| Other Loads | 0 | 0 |
| External Floor Radiant Panel Loss | 2,131 | 0 |
| Internal Floor Radiant Panel Loss | 4,209 | 0 |
| Total Sensible | 29,233 | 7,772 |
| Latent Gain | 0 | 2,332 |
| Total Load | 29,233 | 10,103 |
| Total Area | 2,066 ft ² | 2,131 ft ² |



Calculations meet requirements of CSA F280-12 (R2021 Update 3)

(1) ΔT: Difference between supply air and return air (2) Estimated air flow based on specified supply air ΔT

(*) Heating: apparent sensible effectiveness of the HRV; Cooling: adjusted total recovery efficiency of the HRV/ERV.

Length = ft Area = ft² Temperature = °F Flowrate = USGPM Air Flow = cfm Heat Loss = Btu/hr Unit Heat Loss = Btu/(hr-ft²) Rv = hr-ft²-°F/btu
 Head Loss = ft water RH = Radiant Floor Heating BB = Baseboard FA = Forced Air OTH = Other Heating SM = Snowmelt N = Not Heated

Heating Zones

| Zone | Area | Room Temp | Total Load |
|----------|-------|-----------|------------|
| Zone 101 | 524 | 70 | 8,601 |
| Zone 102 | 476 | 70 | 7,078 |
| Zone 201 | 1,066 | 70 | 13,553 |

Heating Rooms

| Room | Area | Room Temp | Total Load |
|----------------------------------|------|-----------|------------|
| Corridor / Entry | 266 | 70 | 4,662 |
| Dining | 476 | 70 | 7,078 |
| Downstair WC | 45 | 70 | 861 |
| Pantry | 73 | 70 | 937 |
| Rumpus Room | 141 | 70 | 2,140 |
| Bedroom 1 | 146 | 70 | 1,552 |
| Bedroom 2 | 154 | 70 | 2,291 |
| Laundry | 57 | 70 | 337 |
| Library/Office/Upstairs Corridor | 341 | 70 | 3,498 |
| Primary WC | 91 | 70 | 1,668 |
| PrimaryBedroom | 207 | 70 | 3,014 |
| Upstair WC | 69 | 70 | 1,193 |

Cooling Zones

| Zone | Area | Room Temp | Total Load |
|------|-------|-----------|------------|
| C1 | 2,131 | 75 | 10,103 |

Cooling Rooms

| Room | Area | Room Temp | Total Load |
|----------------------------------|------|-----------|------------|
| Corridor / Entry | 266 | 75 | 1,378 |
| Dining | 476 | 75 | 2,505 |
| Downstair WC | 45 | 75 | 163 |
| Mechanical ROom | 66 | 75 | 138 |
| Pantry | 73 | 75 | 143 |
| Rumpus Room | 141 | 75 | 562 |
| Bedroom 1 | 146 | 75 | 689 |
| Bedroom 2 | 154 | 75 | 730 |
| Laundry | 57 | 75 | 137 |
| Library/Office/Upstairs Corridor | 341 | 75 | 1,439 |

Calculations meet requirements of CSA F280-12 (R2021 Update 3)

(1) ΔT : Difference between supply air and return air (2) Estimated air flow based on specified supply air ΔT

(*) Heating: apparent sensible effectiveness of the HRV; Cooling: adjusted total recovery efficiency of the HRV/ERV.

Length = ft Area = ft² Temperature = °F Flowrate = USGPM Air Flow = cfm Heat Loss = Btu/hr Unit Heat Loss = Btu/(hr-ft²) Rv = hr-ft²-°F/btu

Head Loss = ft water RH = Radiant Floor Heating BB = Baseboard FA = Forced Air OTH = Other Heating SM = Snowmelt N = Not Heated

Created Using LoopCAD 2023 (2023-10-24)

Version:23.0.0180 R

| | | | |
|----------------|-----|----|-------|
| Primary WC | 91 | 75 | 691 |
| PrimaryBedroom | 207 | 75 | 1,129 |
| Upstair WC | 69 | 75 | 399 |

CSA Room Details

Corridor / Entry (Ground Floor)

Load Breakdown

| Name | Heat Loss | Heat Gain |
|-----------------------------------|---------------------|---------------------|
| Windows | 794 | 630 |
| Doors | 386 | 0 |
| Above Grade Walls | 734 | 15 |
| Infiltration | 1,407 | 2 |
| Ventilation | 727 | 12 |
| Internal Loads | 0 | 400 |
| External Floor Radiant Panel Loss | 615 | 0 |
| Total Sensible | 4,662 | 1,060 |
| Total Floor Area | 266 ft ² | 266 ft ² |

Constructions


| Type | Description | R-Value | Area | Heating | Cooling |
|-------|---------------------------------------|---------|------|---------|---------|
| Doors | Insulated fiberglass—Polystyrene core | 4.83 | 17 | 386 | 0 |
| Walls | Wall | 48.0 | 315 | 734 | 15 |

Glazings

| Type | Description | Exposure | R-Value | SHGC | Area | Heating | Cooling |
|---------|-------------|----------|---------|------|------|---------|---------|
| Windows | Glass | E | 6.4 | 0.30 | 45 | 794 | 630 |

Foundation

| ID | Code | Description | Area | Heat Loss | Options |
|----|--------|-------------|------|-----------|--|
| F0 | SCB_25 | Slab Floors | 266 | 615 | Slab Insulation: 20.0 hr·ft ² ·°F/btu |



F0

Description

SCB_25

- concrete or soil (for crawl space) floor
- bottom of slab fully insulated except under footing/foundation wall (ie. insulation starts 0.25 m from edge)
- first storey is non-brick veneer or bricks thermally broken from concrete floor

Options

Slab Insulation: 20.0 hr·ft²·°F/btu

Dining (Ground Floor)

Load Breakdown

| Name | Heat Loss | Heat Gain |
|-----------------------------------|---------------------|---------------------|
| Windows | 1,819 | 1,172 |
| Above Grade Walls | 1,046 | 12 |
| Foundation | 96 | 0 |
| Infiltration | 2,140 | 4 |
| Ventilation | 1,107 | 23 |
| Internal Loads | 0 | 716 |
| External Floor Radiant Panel Loss | 871 | 0 |
| Total Sensible | 7,078 | 1,927 |
| Total Floor Area | 476 ft ² | 476 ft ² |

Constructions


| Type | Description | R-Value | Area | Heating | Cooling |
|-------|-------------|---------|------|---------|---------|
| Walls | Wall | 48.0 | 449 | 1,046 | 12 |

Glazings

| Type | Description | Exposure | R-Value | SHGC | Area | Heating | Cooling |
|---------|-------------|----------|---------|------|------|---------|---------|
| Windows | Glass | S | 6.4 | 0.30 | 74 | 1,296 | 757 |
| Windows | Glass | W | 6.4 | 0.30 | 30 | 523 | 415 |

Foundation

| ID | Code | Description | Area | Heat Loss | Options |
|----|--------|-------------|------|-----------|--|
| F0 | SCB_25 | Slab Floors | 476 | 966 | Slab Insulation: 20.0 hr-ft ² -°F/btu |



F0

Description

- SCB_25
 - concrete or soil (for crawl space) floor
 - bottom of slab fully insulated except under footing/foundation wall (ie. insulation starts 0.25 m from edge)
 - first storey is non-brick veneer or bricks thermally broken from concrete floor

Options

Slab Insulation: 20.0 hr-ft²-°F/btu

Downstair WC (Ground Floor)

Load Breakdown

| Name | Heat Loss | Heat Gain |
|-----------------------------------|--------------------|--------------------|
| Windows | 208 | 56 |
| Above Grade Walls | 154 | 0 |
| Foundation | 6 | 0 |
| Infiltration | 261 | 0 |
| Ventilation | 135 | 1 |
| Internal Loads | 0 | 68 |
| External Floor Radiant Panel Loss | 98 | 0 |
| Total Sensible | 861 | 126 |
| Total Floor Area | 45 ft ² | 45 ft ² |

Constructions


| Type | Description | R-Value | Area | Heating | Cooling |
|-------|-------------|---------|------|---------|---------|
| Walls | Wall | 48.0 | 66 | 154 | 0 |

Glazings

| Type | Description | Exposure | R-Value | SHGC | Area | Heating | Cooling |
|---------|-------------|----------|---------|------|------|---------|---------|
| Windows | Glass | N | 6.4 | 0.30 | 12 | 208 | 56 |

Foundation

| ID | Code | Description | Area | Heat Loss | Options |
|----|--------|-------------|------|-----------|--|
| F0 | SCB_25 | Slab Floors | 45 | 104 | Slab Insulation: 20.0 hr·ft ² ·°F/btu |



F0

Description

- SCB_25
 - concrete or soil (for crawl space) floor
 - bottom of slab fully insulated except under footing/foundation wall (ie. insulation starts 0.25 m from edge)
 - first storey is non-brick veneer or bricks thermally broken from concrete floor

Options

Slab Insulation: 20.0 hr·ft²·°F/btu

Mechanical ROom (Ground Floor)

Load Breakdown


| Name | Heat Loss | Heat Gain |
|-------------------|-------------------|--------------------|
| Above Grade Walls | 0 | 7 |
| Ventilation | 0 | 0 |
| Internal Loads | 0 | 99 |
| Total Sensible | 0 | 106 |
| Total Floor Area | 0 ft ² | 66 ft ² |

Constructions

| Type | Description | R-Value | Area | Heating | Cooling |
|-------|-------------|---------|------|---------|---------|
| Walls | Wall | 48.0 | 172 | 0 | 7 |

Foundation

| ID | Code | Description | Area | Heat Loss | Options |
|----|--------|-------------|------|-----------|--|
| F0 | SCB_25 | Slab Floors | 66 | 0 | Slab Insulation: 20.0 hr·ft ² ·°F/btu |



F0

Description

- SCB_25
- concrete or soil (for crawl space) floor
 - bottom of slab fully insulated except under footing/foundation wall (ie. insulation starts 0.25 m from edge)
 - first storey is non-brick veneer or bricks thermally broken from concrete floor

Options

Slab Insulation: 20.0 hr·ft²·°F/btu

Pantry (Ground Floor)

Load Breakdown


| Name | Heat Loss | Heat Gain |
|-----------------------------------|--------------------|--------------------|
| Above Grade Walls | 324 | 0 |
| Infiltration | 281 | 0 |
| Ventilation | 145 | 0 |
| Internal Loads | 0 | 110 |
| External Floor Radiant Panel Loss | 187 | 0 |
| Total Sensible | 937 | 110 |
| Total Floor Area | 73 ft ² | 73 ft ² |

Constructions

| Type | Description | R-Value | Area | Heating | Cooling |
|-------|-------------|---------|------|---------|---------|
| Walls | Wall | 48.0 | 139 | 324 | 0 |

Foundation

| ID | Code | Description | Area | Heat Loss | Options |
|----|--------|-------------|------|-----------|--|
| F0 | SCB_25 | Slab Floors | 73 | 187 | Slab Insulation: 20.0 hr·ft ² ·°F/btu |



F0

Description

- SCB_25
 - concrete or soil (for crawl space) floor
 - bottom of slab fully insulated except under footing/foundation wall (ie. insulation starts 0.25 m from edge)
 - first storey is non-brick veneer or bricks thermally broken from concrete floor

Options

Slab Insulation: 20.0 hr·ft²·°F/btu

Rumpus Room (Ground Floor)

Load Breakdown

| Name | Heat Loss | Heat Gain |
|-----------------------------------|---------------------|---------------------|
| Windows | 260 | 207 |
| Above Grade Walls | 542 | 10 |
| Infiltration | 644 | 1 |
| Ventilation | 333 | 4 |
| Internal Loads | 0 | 211 |
| External Floor Radiant Panel Loss | 362 | 0 |
| Total Sensible | 2,140 | 433 |
| Total Floor Area | 141 ft ² | 141 ft ² |

Constructions


| Type | Description | R-Value | Area | Heating | Cooling |
|-------|-------------|---------|------|---------|---------|
| Walls | Wall | 48.0 | 233 | 542 | 10 |

Glazings

| Type | Description | Exposure | R-Value | SHGC | Area | Heating | Cooling |
|---------|-------------|----------|---------|------|------|---------|---------|
| Windows | Glass | W | 6.4 | 0.30 | 15 | 260 | 207 |

Foundation

| ID | Code | Description | Area | Heat Loss | Options |
|----|--------|-------------|------|-----------|--|
| F0 | SCB_25 | Slab Floors | 141 | 362 | Slab Insulation: 20.0 hr-ft ² -°F/btu |



F0

Description

- SCB_25
- concrete or soil (for crawl space) floor
 - bottom of slab fully insulated except under footing/foundation wall (ie. insulation starts 0.25 m from edge)
 - first storey is non-brick veneer or bricks thermally broken from concrete floor

Options

Slab Insulation: 20.0 hr-ft²-°F/btu

Bedroom 1 (Main Floor)

Load Breakdown

| Name | Heat Loss | Heat Gain |
|-----------------------------------|---------------------|---------------------|
| Windows | 436 | 254 |
| Above Grade Walls | 276 | 0 |
| Infiltration | 385 | 1 |
| Ceiling | 186 | 48 |
| Ventilation | 270 | 6 |
| Internal Loads | 0 | 220 |
| Internal Floor Radiant Panel Loss | 324 | 0 |
| Total Sensible | 1,552 | 530 |
| Total Floor Area | 146 ft ² | 146 ft ² |

Constructions

| Type | Description | R-Value | Area | Heating | Cooling |
|----------------|---|---------|------|---------|---------|
| Walls | Wall | 48.0 | 118 | 276 | 0 |
| Ceilings | Ceiling | 88.0 | 146 | 186 | 48 |
| Radiant Floors | Concrete Thin Slab; R-6.31 Insulation Below Tubing. | 6.31 | 146 | 324 | 0 |

Glazings

| Type | Description | Exposure | R-Value | SHGC | Area | Heating | Cooling |
|---------|-------------|----------|---------|------|------|---------|---------|
| Windows | Glass | S | 6.4 | 0.30 | 25 | 436 | 254 |

Bedroom 2 (Main Floor)

Load Breakdown

| Name | Heat Loss | Heat Gain |
|-----------------------------------|---------------------|---------------------|
| Windows | 436 | 254 |
| Above Grade Walls | 694 | 18 |
| Infiltration | 568 | 1 |
| Ceiling | 196 | 51 |
| Ventilation | 398 | 6 |
| Internal Loads | 0 | 232 |
| Internal Floor Radiant Panel Loss | 1,658 | 0 |
| Total Sensible | 2,291 | 562 |
| Total Floor Area | 154 ft ² | 154 ft ² |

Constructions

| Type | Description | R-Value | Area | Heating | Cooling |
|----------------|---|---------|------|---------|---------|
| Walls | Wall | 48.0 | 298 | 694 | 18 |
| Ceilings | Ceiling | 88.0 | 154 | 196 | 51 |
| Radiant Floors | Concrete Thin Slab; R-6.31 Insulation Below Tubing. | 6.31 | 154 | 1,658 | 0 |

Glazings

| Type | Description | Exposure | R-Value | SHGC | Area | Heating | Cooling |
|---------|-------------|----------|---------|------|------|---------|---------|
| Windows | Glass | S | 6.4 | 0.30 | 25 | 436 | 254 |

Laundry (Main Floor)**Load Breakdown**

| Name | Heat Loss | Heat Gain |
|-----------------------------------|--------------------|--------------------|
| Above Grade Walls | 122 | 0 |
| Infiltration | 84 | 0 |
| Ceiling | 72 | 19 |
| Ventilation | 59 | 0 |
| Internal Loads | 0 | 86 |
| Internal Floor Radiant Panel Loss | 80 | 0 |
| Total Sensible | 337 | 105 |
| Total Floor Area | 57 ft ² | 57 ft ² |

Constructions

| Type | Description | R-Value | Area | Heating | Cooling |
|----------------|---|---------|------|---------|---------|
| Walls | Wall | 48.0 | 53 | 122 | 0 |
| Ceilings | Ceiling | 88.0 | 57 | 72 | 19 |
| Radiant Floors | Concrete Thin Slab; R-6.31 Insulation Below Tubing. | 6.31 | 57 | 80 | 0 |

Calculations meet requirements of CSA F280-12 (R2021 Update 3)

(1) ΔT : Difference between supply air and return air (2) Estimated air flow based on specified supply air ΔT

(*) Heating: apparent sensible effectiveness of the HRV; Cooling: adjusted total recovery efficiency of the HRV/ERV.

Length = ft Area = ft² Temperature = °F Flowrate = USGPM Air Flow = cfm Heat Loss = Btu/hr Unit Heat Loss = Btu/(hr-ft²) Rv = hr-ft²-°F/btu
Head Loss = ft water RH = Radiant Floor Heating BB = Baseboard FA = Forced Air OTH = Other Heating SM = Snowmelt N = Not Heated

Created Using LoopCAD 2023 (2023-10-24)

Version:23.0.0180 R

Library/Office/Upstairs Corridor (Main)

Load Breakdown

| Name | Heat Loss | Heat Gain |
|-----------------------------------|---------------------|---------------------|
| Windows | 941 | 468 |
| Above Grade Walls | 648 | 0 |
| Infiltration | 868 | 2 |
| Ceiling | 434 | 112 |
| Ventilation | 607 | 11 |
| Internal Loads | 0 | 514 |
| Internal Floor Radiant Panel Loss | 856 | 0 |
| Total Sensible | 3,498 | 1,107 |
| Total Floor Area | 341 ft ² | 341 ft ² |

Constructions

| Type | Description | R-Value | Area | Heating | Cooling |
|----------------|---|---------|------|---------|---------|
| Walls | Wall | 48.0 | 278 | 648 | 0 |
| Ceilings | Ceiling | 88.0 | 341 | 434 | 112 |
| Radiant Floors | Concrete Thin Slab; R-6.31 Insulation Below Tubing. | 6.31 | 341 | 856 | 0 |

Glazings

| Type | Description | Exposure | R-Value | SHGC | Area | Heating | Cooling |
|---------|-------------|----------|---------|------|------|---------|---------|
| Windows | Glass | N | 6.4 | 0.30 | 15 | 261 | 71 |
| Windows | Glass | S | 6.4 | 0.30 | 39 | 680 | 397 |

Primary WC (Main Floor)

Load Breakdown

| Name | Heat Loss | Heat Gain |
|-----------------------------------|--------------------|--------------------|
| Windows | 436 | 346 |
| Above Grade Walls | 413 | 10 |
| Infiltration | 414 | 1 |
| Ceiling | 116 | 30 |
| Ventilation | 290 | 7 |
| Internal Loads | 0 | 137 |
| Internal Floor Radiant Panel Loss | 385 | 0 |
| Total Sensible | 1,668 | 531 |
| Total Floor Area | 91 ft ² | 91 ft ² |

Constructions

| Type | Description | R-Value | Area | Heating | Cooling |
|----------------|---|---------|------|---------|---------|
| Walls | Wall | 48.0 | 177 | 413 | 10 |
| Ceilings | Ceiling | 88.0 | 91 | 116 | 30 |
| Radiant Floors | Concrete Thin Slab; R-6.31 Insulation Below Tubing. | 6.31 | 91 | 385 | 0 |

Glazings

| Type | Description | Exposure | R-Value | SHGC | Area | Heating | Cooling |
|---------|-------------|----------|---------|------|------|---------|---------|
| Windows | Glass | W | 6.4 | 0.30 | 25 | 436 | 346 |

PrimaryBedroom (Main Floor)

Load Breakdown

| Name | Heat Loss | Heat Gain |
|-----------------------------------|---------------------|---------------------|
| Windows | 695 | 460 |
| Above Grade Walls | 785 | 16 |
| Infiltration | 748 | 2 |
| Ceiling | 263 | 68 |
| Ventilation | 523 | 10 |
| Internal Loads | 0 | 312 |
| Internal Floor Radiant Panel Loss | 623 | 0 |
| Total Sensible | 3,014 | 869 |
| Total Floor Area | 207 ft ² | 207 ft ² |

Constructions

| Type | Description | R-Value | Area | Heating | Cooling |
|----------------|---|---------|------|---------|---------|
| Walls | Wall | 48.0 | 337 | 785 | 16 |
| Ceilings | Ceiling | 88.0 | 207 | 263 | 68 |
| Radiant Floors | Concrete Thin Slab; R-6.31 Insulation Below Tubing. | 6.31 | 207 | 623 | 0 |

Glazings

| Type | Description | Exposure | R-Value | SHGC | Area | Heating | Cooling |
|---------|-------------|----------|---------|------|------|---------|---------|
| Windows | Glass | S | 6.4 | 0.30 | 25 | 434 | 254 |
| Windows | Glass | W | 6.4 | 0.30 | 15 | 261 | 207 |

Upstair WC (Main Floor)

Load Breakdown

| Name | Heat Loss | Heat Gain |
|-----------------------------------|--------------------|--------------------|
| Windows | 208 | 165 |
| Above Grade Walls | 395 | 11 |
| Infiltration | 296 | 1 |
| Ceiling | 87 | 23 |
| Ventilation | 207 | 4 |
| Internal Loads | 0 | 103 |
| Internal Floor Radiant Panel Loss | 281 | 0 |
| Total Sensible | 1,193 | 307 |
| Total Floor Area | 69 ft ² | 69 ft ² |

Constructions

| Type | Description | R-Value | Area | Heating | Cooling |
|----------------|---|---------|------|---------|---------|
| Walls | Wall | 48.0 | 169 | 395 | 11 |
| Ceilings | Ceiling | 88.0 | 69 | 87 | 23 |
| Radiant Floors | Concrete Thin Slab; R-6.31 Insulation Below Tubing. | 6.31 | 69 | 281 | 0 |

Glazings

| Type | Description | Exposure | R-Value | SHGC | Area | Heating | Cooling |
|---------|-------------|----------|---------|------|------|---------|---------|
| Windows | Glass | E | 6.4 | 0.30 | 12 | 208 | 165 |

Disclaimers

With the permission of Canadian Standards Association, material is reproduced from CSA Standard, CSA F280-12 (Revision 2021 Update 3), Determining the Required Capacity of Residential Space Heating and Cooling Appliances which is copyrighted by Canadian Standards Association, 178 Rexdale Blvd., Toronto, Ontario, M9W 1R3, www.shopcsa.ca. While use of this material has been authorized, CSA shall not be responsible for the manner in which the information is presented, nor for any interpretations thereof.

Cold weather humidification, or some lifestyles that produce excessive moisture, may cause condensation to occur if the absolute humidity of the indoor air is too high for the momentary circumstances. Condensation can occur on surfaces or concealed within the structure, and can lead to mold, mildew, frost damage, and moisture damage. The software does not perform calculations for the estimation or detection of possible condensation problems, and it is the designers (i.e. software users) responsibility to do so independently if required.

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.

Calculations meet requirements of CSA F280-12 (R2021 Update 3)

(1) ΔT : Difference between supply air and return air (2) Estimated air flow based on specified supply air ΔT

(*) Heating: apparent sensible effectiveness of the HRV; Cooling: adjusted total recovery efficiency of the HRV/ERV.

Length = ft Area = ft² Temperature = °F Flowrate = USGPM Air Flow = cfm Heat Loss = Btu/hr Unit Heat Loss = Btu/(hr-ft²) Rv = hr-ft²-°F/btu
Head Loss = ft water RH = Radiant Floor Heating BB = Baseboard FA = Forced Air OTH = Other Heating SM = Snowmelt N = Not Heated

Created Using LoopCAD 2023 (2023-10-24)

Version:23.0.0180 R

See end of report for important Notes and Disclaimers.



Heating System Summary

Project #: L211
October 03, 2023

Project Information

Project #: L211
Name: Matthew Holmes
Location: 10403, Y1A7A1, Whitehorse, Yukon, Canada

Notes:

Project Summary

| | | | | | |
|--------------------------|-----------------------------|------------------------|----------------------|---------------------------|---------------|
| Load Calculation Method: | CSA F280-12 | Total Circuit Lengths: | | Component Losses: | 14,206 Btu/hr |
| Design Location: | Whitehorse, Yukon Territory | Barrier PEX 1/2" | 2,320 ft | Infiltration/Ventilation: | 12,896 Btu/hr |
| Outdoor Temperature: | -41.8 °F | | | Radiant Back Losses: | 2,131 Btu/hr |
| Floorplans / Levels: | | Total RH Circuits: | 10 | Total Heating Load: | 29,233 Btu/hr |
| Ground Floor | 1,000 ft ² | Total Manifolds: | 1 | | |
| Main Floor | 1,066 ft ² | Total Zones: | 3 | Radiant Heating: | 26,752 Btu/hr |
| Total Area: | 2,066 ft ² | | | Radiant Back Losses: | 2,131 Btu/hr |
| | | Fluid Type: | 30% Propylene Glycol | Other: | 350 Btu/hr |
| | | Total Tubing Volume: | 21.35 USG | Total Heating Load: | 29,233 Btu/hr |
| | | Glycol Volume: | 6.41 USG | | |
| | | Surface Temperature: | 82 - 84 °F | | |

Zone Heating Summary

| Zone # | Gross Area | Construction | Heating Types | RH ¹ Circuits | Total Tubing | Manifolds | Flowrate | Head Loss (Circuit Only) | RH Load ² | Supplemental | Zone Load ³ |
|----------|------------|--------------------|---------------|--------------------------|--------------|-----------|----------|--------------------------|----------------------|--------------|------------------------|
| Zone 101 | 524 | Embedded Slab | RH,OTH | 3 | 578 | 1 | 1.33 | 2.2 | 8,508 | 94 | 8,601 |
| Zone 102 | 476 | Embedded Slab | RH | 2 | 516 | 1 | 0.88 | 3.1 | 7,078 | 0 | 7,078 |
| Zone 201 | 1,066 | Concrete Thin Slab | RH,OTH | 5 | 1,226 | 1 | 2.34 | 4.2 | 17,506 | 256 | 17,762 |

(1) Complete circuits assigned to this zone. (2) Total Radiant heating load for rooms in zone, including all panel back loss. (3) Total load for zone including all panel back loss. Does not account for reclaimed loss within building envelope.

Length = ft Area = ft² Temperature = °F Flowrate = USGPM Air Flow = cfm Heat Loss = Btu/hr Unit Heat Loss = Btu/(hr-ft²) Rv = hr-ft²-°F/btu
Head Loss = ft water RH = Radiant Floor Heating BB = Baseboard FA = Forced Air OTH = Other Heating SM = Snowmelt N = Not Heated

Created Using LoopCAD 2023 (2023-10-24)
Version: 23.0.0180 R

See end of report for important Notes and Disclaimers.

Room Heating Summary (By Construction Type)**Embedded Slab**

| Zone # | Room Name | Heating Type | Floor Area | Heated Area | Manifold # | Tube Size | RH Circuits ¹ | Tube Spacing | Tubing In Room | Floor Cover RV | Required Temp. | Unit RH Load | RH Load ² | Supplemental | Total Load ³ |
|----------|------------------|--------------|------------|-------------|------------|-----------|--------------------------|--------------|----------------|----------------|----------------|--------------|----------------------|--------------|-------------------------|
| Zone 101 | Corridor / Entry | RH | 207 | 203 | Manifold 1 | 1/2" | 1 | 10 | 259 | 0.5 | 114 | 23.0 | 4,662 | 0 | 4,662 |
| Zone 101 | Downstair WC | RH, OTH | 29 | 27 | Manifold 1 | 1/2" | 1 | 10 | 34 | 0.5 | 120 | 28.6 | 768 | 94 | 861 |
| Zone 101 | Pantry | RH | 48 | 48 | n/a | n/a | 0 | 10 | 55 | 0.5 | 0 | 19.5 | 937 | 0 | 937 |
| Zone 101 | Rumpus Room | RH | 107 | 107 | Manifold 1 | 1/2" | 1 | 10 | 124 | 0.5 | 108 | 20.0 | 2,140 | 0 | 2,140 |
| Zone 102 | Dining | RH | 406 | 352 | Manifold 1 | 1/2" | 2 | 10 | 419 | 0.5 | 110 | 20.1 | 7,078 | 0 | 7,078 |

(1) Circuits assigned to this room. Leaders from other rooms may not be counted. (2) Includes panel back loss. (3) Total load including panel back loss. Does not account for reclaimed loss within building envelope.

Concrete Thin Slab

| Zone # | Room Name | Heating Type | Floor Area | Heated Area | Manifold # | Tube Size | RH Circuits ¹ | Tube Spacing | Tubing In Room | Floor Cover RV | Required Temp. | Unit RH Load | RH Load ² | Supplemental | Total Load ³ |
|----------|---|--------------|------------|-------------|------------|-----------|--------------------------|--------------|----------------|----------------|----------------|--------------|----------------------|--------------|-------------------------|
| Zone 201 | Bedroom 1 | RH | 117 | 117 | Manifold 1 | 1/2" | 1 | 10 | 143 | 0.5 | 101 | 16.1 | 1,876 | 0 | 1,876 |
| Zone 201 | Bedroom 2 | RH | 119 | 119 | n/a | n/a | 0 | 10 | 155 | 0.5 | 0 | 33.3 | 3,950 | 0 | 3,950 |
| Zone 201 | Laundry | RH | 40 | 40 | Manifold 1 | 1/2" | 1 | 10 | 53 | 0.5 | 93 | 10.4 | 417 | 0 | 417 |
| Zone 201 | Library/Office/ Upstairs Corridor | RH | 279 | 232 | Manifold 1 | 1/2" | 1 | 10 | 287 | 0.5 | 104 | 18.8 | 4,354 | 0 | 4,354 |
| Zone 201 | Primary WC | RH, OTH | 65 | 62 | n/a | n/a | 0 | 10 | 80 | 0.5 | 0 | 31.3 | 1,926 | 128 | 2,053 |
| Zone 201 | PrimaryBedroom | RH | 166 | 166 | Manifold 1 | 1/2" | 1 | 10 | 205 | 0.5 | 108 | 21.9 | 3,637 | 0 | 3,637 |
| Zone 201 | Upstair WC | RH, OTH | 46 | 43 | Manifold 1 | 1/2" | 1 | 10 | 50 | 0.5 | 120 | 31.5 | 1,346 | 129 | 1,474 |

(1) Circuits assigned to this room. Leaders from other rooms may not be counted. (2) Includes panel back loss. (3) Total load including panel back loss. Does not account for reclaimed loss within building envelope.

Manifold Summary

| Manifold Name | # Zones | # Circuits | Flow | Head Loss ¹ | Required Temp. | Supplied Temp. | Temp Drop | Manifold Type | Control Type | # Actuators | S/R Length ² | S/R Pipe |
|---------------|---------|------------|------|------------------------|----------------|----------------|-----------|-----------------|--------------|-------------|-------------------------|----------|
| Manifold 1 | 3 | 10 | 4.56 | 4.9 | 120 | 120 | 20 | Stainless Steel | Circuit | 10 | - | - |
| Total | 3 | 10 | 4.56 | 4.9 | - | - | - | - | - | 10 | - | - |

(1) Total Head loss includes manifold, circuits and supply/return piping if specified. (2) S/R Length = one way

Disclaimers

With the permission of Canadian Standards Association, material is reproduced from CSA Standard, CSA F280-12 (Revision 2021 Update 3), Determining the Required Capacity of Residential Space Heating and Cooling Appliances which is copyrighted by Canadian Standards Association, 178 Rexdale Blvd., Toronto, Ontario, M9W 1R3, www.shopcsa.ca. While use of this material has been authorized, CSA shall not be responsible for the manner in which the information is presented, nor for any interpretations thereof.

Cold weather humidification, or some lifestyles that produce excessive moisture, may cause condensation to occur if the absolute humidity of the indoor air is too high for the momentary circumstances. Condensation can occur on surfaces or concealed within the structure, and can lead to mold, mildew, frost damage, and moisture damage. The software does not perform calculations for the estimation or detection of possible condensation problems, and it is the designers (i.e. software users) responsibility to do so independently if required.

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.



Project Information

Project #: L211
Name: Matthew Holmes
Location: 10403, Y1A7A1, Whitehorse, Yukon, Canada

Notes:

Design Conditions and Summary

| | | | | | |
|--------------------------|-----------------------------|-----------------------|----------------------|---------------------------|---------------|
| Load Calculation Method: | CSA F280-12 | Total Tubing Lengths: | | Component Losses: | 14,206 Btu/hr |
| Design Location: | Whitehorse, Yukon Territory | Barrier PEX 1/2" | 2,320 ft | Infiltration/Ventilation: | 12,896 Btu/hr |
| Outdoor Temperature: | -41.8 °F | | | Radiant Back Losses: | 2,131 Btu/hr |
| Floorplans / Levels: | | Total RH Circuits: | 10 | Total Heating Load: | 29,233 Btu/hr |
| Ground Floor | 1,000 ft ² | Total Manifolds: | 1 | | |
| Main Floor | 1,066 ft ² | Total Zones: | 3 | Radiant Heating: | 26,752 Btu/hr |
| Total Area: | 2,066 ft ² | | | Radiant Back Losses: | 2,131 Btu/hr |
| | | Fluid Type: | 30% Propylene Glycol | Other: | 350 Btu/hr |
| | | Total Tubing Volume: | 21.35 USG | Total Heating Load: | 29,233 Btu/hr |
| | | Glycol Volume: | 6.41 USG | | |

Zone Heating Summary

| Zone # | Area | Heating Types | RH Circuits | Flowrate | Head Loss | Supplemental | Rooms |
|--------------|--------------|---------------|-------------|-------------|------------|--------------|--|
| 101 | 524 | RH,OTH | 3 | 1.33 | 2.9 | 94 | Pantry, Rumpus Room, Corridor / Entry, Downstair WC |
| 102 | 476 | RH | 2 | 0.88 | 3.7 | 0 | Dining |
| 201 | 1,066 | RH,OTH | 5 | 2.34 | 4.9 | 256 | Primary WC, Laundry, Primary Bedroom, Bedroom 1, Bedroom 2, Library/Office/Upstairs Corridor, Upstair WC |
| Total | 2,066 | RH,OTH | 10 | 4.56 | 4.9 | 350 | |

*RH Loads include internal panel back loss that may not be included in the project total.

Room Heating Summary

Ground Floor

Corridor / Entry

| | | | | | |
|----------------------|---------------------|-------------------------|---------------------|---------------------------|--------------|
| Total Area: | 266 ft ² | <u>Radiant Heating:</u> | | <u>Load/Loss Summary:</u> | |
| Heated by: | RH | Heated Area: | 203 ft ² | Room Design Load: | 4,047 Btu/hr |
| Room Temperature: | 70 °F | Tubing in Floor: | 272 ft | Radiant Load: | 4,662 Btu/hr |
| Floor Covering (Rv): | 0.5 | Circuits in Room: | 1 | Baseboard Load: | 0 Btu/hr |
| | | Tube Spacing: | 10 | Forced Air Load: | 0 Btu/hr |
| | | Required Surface Temp: | 81 °F | Other Load: | 0 Btu/hr |
| | | Required Water Temp: | 114 °F | | |
| | | Est. Peak Output: | 5,035 Btu/hr | Radiant Back Loss: | 615 Btu/hr |
| | | | | Recovered Back Loss: | 0 Btu/hr |
| | | | | Total Heat Loss: | 4,662 Btu/hr |

Dining

| | | | | | |
|----------------------|---------------------|-------------------------|---------------------|---------------------------|--------------|
| Total Area: | 476 ft ² | <u>Radiant Heating:</u> | | <u>Load/Loss Summary:</u> | |
| Heated by: | RH | Heated Area: | 352 ft ² | Room Design Load: | 6,208 Btu/hr |
| Room Temperature: | 70 °F | Tubing in Floor: | 434 ft | Radiant Load: | 7,078 Btu/hr |
| Floor Covering (Rv): | 0.5 | Circuits in Room: | 2 | Baseboard Load: | 0 Btu/hr |
| | | Tube Spacing: | 10 | Forced Air Load: | 0 Btu/hr |
| | | Required Surface Temp: | 80 °F | Other Load: | 0 Btu/hr |
| | | Required Water Temp: | 110 °F | | |
| | | Est. Peak Output: | 8,110 Btu/hr | Radiant Back Loss: | 871 Btu/hr |
| | | | | Recovered Back Loss: | 0 Btu/hr |
| | | | | Total Heat Loss: | 7,078 Btu/hr |

Downstair WC

Total Area: 45 ft²
 Heated by: RH,OTH
 Room Temperature: 70 °F
 Floor Covering (Rv): 0.5

Radiant Heating:
 Heated Area: 27 ft²
 Tubing in Floor: 36 ft
 Circuits in Room: 1
 Tube Spacing: 10
 Required Surface Temp: 83 °F
 Required Water Temp: 120 °F
 Est. Peak Output: 670 Btu/hr

Supplemental Req'd: 94 Btu/hr

Load/Loss Summary:
Room Design Load: 670 Btu/hr
 Radiant Load: 768 Btu/hr
 Baseboard Load: 0 Btu/hr
 Forced Air Load: 0 Btu/hr
 Other Load: 94 Btu/hr
 Radiant Back Loss: 98 Btu/hr
 Recovered Back Loss: 0 Btu/hr
 Total Heat Loss: 861 Btu/hr

Pantry

Total Area: 73 ft²
 Heated by: RH
 Room Temperature: 70 °F
 Floor Covering (Rv): 0.5

Radiant Heating:
 Heated Area: 48 ft²
 Tubing in Floor: 58 ft
 Circuits in Room: 0
 Tube Spacing: 10
 Required Surface Temp: 79 °F
 Required Water Temp: 106 °F
 Est. Peak Output: 1,168 Btu/hr

Load/Loss Summary:
Room Design Load: 751 Btu/hr
 Radiant Load: 937 Btu/hr
 Baseboard Load: 0 Btu/hr
 Forced Air Load: 0 Btu/hr
 Other Load: 0 Btu/hr
 Radiant Back Loss: 187 Btu/hr
 Recovered Back Loss: 0 Btu/hr
 Total Heat Loss: 937 Btu/hr

Rumpus Room

Total Area: 141 ft²
 Heated by: RH
 Room Temperature: 70 °F
 Floor Covering (Rv): 0.5

Radiant Heating:
 Heated Area: 107 ft²
 Tubing in Floor: 128 ft
 Circuits in Room: 1
 Tube Spacing: 10
 Required Surface Temp: 79 °F
 Required Water Temp: 108 °F
 Est. Peak Output: 2,611 Btu/hr

Load/Loss Summary:
Room Design Load: 1,779 Btu/hr
 Radiant Load: 2,140 Btu/hr
 Baseboard Load: 0 Btu/hr
 Forced Air Load: 0 Btu/hr
 Other Load: 0 Btu/hr
 Radiant Back Loss: 362 Btu/hr
 Recovered Back Loss: 0 Btu/hr
 Total Heat Loss: 2,140 Btu/hr

Main Floor

Bedroom 1

| | | | | | |
|----------------------|---------------------|-------------------------|---------------------|---------------------------|--------------|
| Total Area: | 146 ft ² | <u>Radiant Heating:</u> | | <u>Load/Loss Summary:</u> | |
| Heated by: | RH | Heated Area: | 117 ft ² | Room Design Load: | 1,552 Btu/hr |
| Room Temperature: | 70 °F | Tubing in Floor: | 147 ft | Radiant Load: | 1,876 Btu/hr |
| Floor Covering (RV): | 0.5 | Circuits in Room: | 1 | Baseboard Load: | 0 Btu/hr |
| | | Tube Spacing: | 10 | Forced Air Load: | 0 Btu/hr |
| | | Required Surface Temp: | 77 °F | Other Load: | 0 Btu/hr |
| | | Required Water Temp: | 101 °F | | |
| | | Est. Peak Output: | 2,901 Btu/hr | Radiant Back Loss: | 324 Btu/hr |
| | | | | Recovered Back Loss: | -324 Btu/hr |
| | | | | Total Heat Loss: | 1,552 Btu/hr |

Bedroom 2

| | | | | | |
|----------------------|---------------------|-------------------------|---------------------|---------------------------|---------------|
| Total Area: | 154 ft ² | <u>Radiant Heating:</u> | | <u>Load/Loss Summary:</u> | |
| Heated by: | RH | Heated Area: | 119 ft ² | Room Design Load: | 2,291 Btu/hr |
| Room Temperature: | 70 °F | Tubing in Floor: | 159 ft | Radiant Load: | 3,950 Btu/hr |
| Floor Covering (RV): | 0.5 | Circuits in Room: | 0 | Baseboard Load: | 0 Btu/hr |
| | | Tube Spacing: | 9 | Forced Air Load: | 0 Btu/hr |
| | | Required Surface Temp: | 81 °F | Other Load: | 0 Btu/hr |
| | | Required Water Temp: | 105 °F | | |
| | | Est. Peak Output: | 3,017 Btu/hr | Radiant Back Loss: | 1,658 Btu/hr |
| | | | | Recovered Back Loss: | -1,658 Btu/hr |
| | | | | Total Heat Loss: | 2,291 Btu/hr |

Laundry

| | | | | | |
|----------------------|--------------------|-------------------------|--------------------|---------------------------|------------|
| Total Area: | 57 ft ² | <u>Radiant Heating:</u> | | <u>Load/Loss Summary:</u> | |
| Heated by: | RH | Heated Area: | 40 ft ² | Room Design Load: | 337 Btu/hr |
| Room Temperature: | 70 °F | Tubing in Floor: | 54 ft | Radiant Load: | 417 Btu/hr |
| Floor Covering (RV): | 0.5 | Circuits in Room: | 1 | Baseboard Load: | 0 Btu/hr |
| | | Tube Spacing: | 10 | Forced Air Load: | 0 Btu/hr |
| | | Required Surface Temp: | 75 °F | Other Load: | 0 Btu/hr |
| | | Required Water Temp: | 93 °F | | |
| | | Est. Peak Output: | 1,017 Btu/hr | Radiant Back Loss: | 80 Btu/hr |
| | | | | Recovered Back Loss: | -80 Btu/hr |
| | | | | Total Heat Loss: | 337 Btu/hr |

Library/Office/Upstairs Corridor

Total Area: 341 ft²
 Heated by: RH
 Room Temperature: 70 °F
 Floor Covering (Rv): 0.5

Radiant Heating:
 Heated Area: 232 ft²
 Tubing in Floor: 293 ft
 Circuits in Room: 1
 Tube Spacing: 10
 Required Surface Temp: 78 °F
 Required Water Temp: 104 °F
 Est. Peak Output: 5,787 Btu/hr

Load/Loss Summary:
Room Design Load: 3,498 Btu/hr
 Radiant Load: 4,354 Btu/hr
 Baseboard Load: 0 Btu/hr
 Forced Air Load: 0 Btu/hr
 Other Load: 0 Btu/hr
 Radiant Back Loss: 856 Btu/hr
 Recovered Back Loss: -856 Btu/hr
 Total Heat Loss: 3,498 Btu/hr

Primary WC

Total Area: 91 ft²
 Heated by: RH,OTH
 Room Temperature: 70 °F
 Floor Covering (Rv): 0.5

Radiant Heating:
 Heated Area: 62 ft²
 Tubing in Floor: 81 ft
 Circuits in Room: 0
 Tube Spacing: 9
 Required Surface Temp: 84 °F
 Required Water Temp: 120 °F
 Est. Peak Output: 1,540 Btu/hr

Supplemental Req'd: 128 Btu/hr

Load/Loss Summary:
Room Design Load: 1,540 Btu/hr
 Radiant Load: 1,926 Btu/hr
 Baseboard Load: 0 Btu/hr
 Forced Air Load: 0 Btu/hr
 Other Load: 128 Btu/hr
 Radiant Back Loss: 385 Btu/hr
 Recovered Back Loss: -385 Btu/hr
 Total Heat Loss: 1,668 Btu/hr

Primary Bedroom

Total Area: 207 ft²
 Heated by: RH
 Room Temperature: 70 °F
 Floor Covering (Rv): 0.5

Radiant Heating:
 Heated Area: 166 ft²
 Tubing in Floor: 210 ft
 Circuits in Room: 1
 Tube Spacing: 10
 Required Surface Temp: 80 °F
 Required Water Temp: 108 °F
 Est. Peak Output: 4,107 Btu/hr

Load/Loss Summary:
Room Design Load: 3,014 Btu/hr
 Radiant Load: 3,637 Btu/hr
 Baseboard Load: 0 Btu/hr
 Forced Air Load: 0 Btu/hr
 Other Load: 0 Btu/hr
 Radiant Back Loss: 623 Btu/hr
 Recovered Back Loss: -623 Btu/hr
 Total Heat Loss: 3,014 Btu/hr

Upstair WC

Total Area: 69 ft²
 Heated by: RH,OTH
 Room Temperature: 70 °F
 Floor Covering (Rv): 0.5

Radiant Heating:
 Heated Area: 43 ft²
 Tubing in Floor: 51 ft
 Circuits in Room: 1
 Tube Spacing: 10
 Required Surface Temp: 83 °F
 Required Water Temp: 120 °F
 Est. Peak Output: 1,064 Btu/hr

Supplemental Req'd: 129 Btu/hr

Load/Loss Summary:
Room Design Load: 1,064 Btu/hr
 Radiant Load: 1,346 Btu/hr
 Baseboard Load: 0 Btu/hr
 Forced Air Load: 0 Btu/hr
 Other Load: 129 Btu/hr
 Radiant Back Loss: 281 Btu/hr
 Recovered Back Loss: -281 Btu/hr
 Total Heat Loss: 1,193 Btu/hr

Radiant Heating Details

Manifold Summary

| Manifold Name | Zones | Circuits | Flowrate | Head Loss ¹ | Required Temp. | Supplied Temp. | Temp Drop | Manifold Type | Control Type | Actuators | S/R Length ² | S/R Pipe |
|---------------|-------|----------|----------|------------------------|----------------|----------------|-----------|-----------------|--------------|-----------|-------------------------|----------|
| Manifold 1 | 3 | 10 | 4.56 | 4.9 | 120 | 120 | 20 | Stainless Steel | Circuit | 10 | - | - |
| Total | 3 | 10 | 4.56 | 4.9 | 120 | - | - | - | - | 10 | - | - |

(1) Total Head loss includes manifold, circuits and supply/return piping if specified., (2) S/R Length = one way

Tubing Circuit Details

Manifold 1

| Circuit | Rooms Served | Total Length | Tube Spacing | Area Covered | Tubing | Flowrate | Head Loss ¹ | Temp Drop | Load | Actuator |
|---------|----------------------------------|--------------|--------------|--------------|------------------|----------|------------------------|-----------|--------|----------|
| A-1 | Dining | 262 | 10 | 167 | Barrier PEX 1/2" | 0.44 | 3.1 | 20 | 3,374 | Yes |
| A-2 | Dining | 253 | 10 | 192 | Barrier PEX 1/2" | 0.44 | 3.0 | 20 | 3,863 | Yes |
| A-3 | Corridor / Entry | 193 | 10 | 130 | Barrier PEX 1/2" | 0.44 | 2.2 | 20 | 2,824 | Yes |
| A-4 | Rumpus Room | 192 | 10 | 126 | Barrier PEX 1/2" | 0.44 | 2.2 | 20 | 2,630 | Yes |
| A-5 | Downstair WC | 193 | 10 | 125 | Barrier PEX 1/2" | 0.44 | 2.2 | 20 | 2,868 | Yes |
| B-1 | Laundry | 246 | 10 | 161 | Barrier PEX 1/2" | 0.44 | 2.9 | 20 | 3,079 | Yes |
| B-2 | Library/Office/Upstairs Corridor | 253 | 10 | 157 | Barrier PEX 1/2" | 0.44 | 2.9 | 20 | 2,949 | Yes |
| B-3 | Bedroom 1 | 248 | 10 | 152 | Barrier PEX 1/2" | 0.44 | 2.9 | 20 | 2,872 | Yes |
| B-4 | Upstair WC | 229 | 10 | 150 | Barrier PEX 1/2" | 0.57 | 4.2 | 20 | 4,787 | Yes |
| B-6 | PrimaryBedroom | 251 | 10 | 158 | Barrier PEX 1/2" | 0.44 | 2.9 | 20 | 3,818 | Yes |
| Total | - | 2,320 | | 1,518 | - | 4.56 | 4.2 | | 33,065 | 10 |

(1) Head loss for circuit tubing only

Disclaimers

With the permission of Canadian Standards Association, material is reproduced from CSA Standard, CSA F280-12 (Revision 2021 Update 3), Determining the Required Capacity of Residential Space Heating and Cooling Appliances which is copyrighted by Canadian Standards Association, 178 Rexdale Blvd., Toronto, Ontario, M9W 1R3, www.shopcsa.ca. While use of this material has been authorized, CSA shall not be responsible for the manner in which the information is presented, nor for any interpretations thereof.

Cold weather humidification, or some lifestyles that produce excessive moisture, may cause condensation to occur if the absolute humidity of the indoor air is too high for the momentary circumstances. Condensation can occur on surfaces or concealed within the structure, and can lead to mold, mildew, frost damage, and moisture damage. The software does not perform calculations for the estimation or detection of possible condensation problems, and it is the designers (i.e. software users) responsibility to do so independently if required.

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.



Water Supply Summary

Project #:L211
 October 03, 2023

Project Information

Project #: L211
 Name: Matthew Holmes
 Location: 10403, Y1A7A1, Whitehorse, Yukon, Canada

Notes:

Supply Summary

| Name | Temp | Total Fluid Vol | Total Flow | Head Loss ¹ | Load ² | # Circuits | # Zones |
|-------------------|------|-----------------|------------|------------------------|-------------------|------------|---------|
| Water Temperature | 120 | 21.35 | 4.56 | 4.9 | 33,065 | 10 | 3 |

(1) Head loss includes manifolds, circuits, and supply/return piping if specified, may also contain control valve losses. (2) Load includes all panel back losses.

Manifold Summary

| Manifold Name | Circuits | Flowrate | Required Temp. | Supplied Temp. | Manifold Type | S/R Length ¹ | S/R Pipe | Manifold Head Loss | Circuit Head Loss | S/R Head Loss | Total Head Loss ² |
|---------------|----------|----------|----------------|----------------|-----------------|-------------------------|----------|--------------------|-------------------|---------------|------------------------------|
| Manifold 1 | 10 | 4.56 | 120 | 120 | Stainless Steel | - | - | 0.6 | 4.2 | 0.0 | 4.9 |
| Total | 10 | 4.56 | - | - | - | - | - | 0.6 | 4.2 | 0.0 | 4.9 |

(1) S/R Length = one way, (2) Total Head loss includes manifold, circuits and supply/return piping if specified.

Water Temperature (120 °F)**Manifold 1 (120 °F, Stainless Steel, 10 Circuits)**

| Circuit | Rooms Served | Total Length | Tube Spacing | Area Covered | Tubing | Flowrate | Head Loss ¹ | Temp Drop ² | Load ³ | Actuator |
|---------|----------------------------------|--------------|--------------|--------------|------------------|----------|------------------------|------------------------|-------------------|----------|
| A-1 | Dining | 262 | 10 | 167 | Barrier PEX 1/2" | 0.44 | 3.1 | 20 | 3,374 | Yes |
| A-2 | Dining | 253 | 10 | 192 | Barrier PEX 1/2" | 0.44 | 3.0 | 20 | 3,863 | Yes |
| A-3 | Corridor / Entry | 193 | 10 | 128 | Barrier PEX 1/2" | 0.44 | 2.2 | 20 | 2,824 | Yes |
| A-4 | Rumpus Room | 192 | 10 | 126 | Barrier PEX 1/2" | 0.44 | 2.2 | 20 | 2,630 | Yes |
| A-5 | Downstair WC | 193 | 10 | 125 | Barrier PEX 1/2" | 0.44 | 2.2 | 20 | 2,868 | Yes |
| B-1 | Laundry | 246 | 10 | 161 | Barrier PEX 1/2" | 0.44 | 2.9 | 20 | 3,079 | Yes |
| B-2 | Library/Office/Upstairs Corridor | 253 | 10 | 157 | Barrier PEX 1/2" | 0.44 | 2.9 | 20 | 2,949 | Yes |
| B-3 | Bedroom 1 | 248 | 10 | 152 | Barrier PEX 1/2" | 0.44 | 2.9 | 20 | 2,872 | Yes |
| B-4 | Upstair WC | 229 | 10 | 150 | Barrier PEX 1/2" | 0.57 | 4.2 | 20 | 4,787 | Yes |
| B-6 | PrimaryBedroom | 251 | 10 | 158 | Barrier PEX 1/2" | 0.44 | 2.9 | 20 | 3,818 | Yes |
| Total | - | 2,320 | | 1,515 | - | 4.56 | 4.2 | - | 33,065 | 10 |

(1) Head loss for circuit tubing only. (2) Design Temp Drop (Estimated Actual Drop). (3) Required load. Includes panel back losses. Does not reflect maximum capacity of the circuit.

Disclaimers

With the permission of Canadian Standards Association, material is reproduced from CSA Standard, CSA F280-12 (Revision 2021 Update 3), Determining the Required Capacity of Residential Space Heating and Cooling Appliances which is copyrighted by Canadian Standards Association, 178 Rexdale Blvd., Toronto, Ontario, M9W 1R3, www.shopcsa.ca. While use of this material has been authorized, CSA shall not be responsible for the manner in which the information is presented, nor for any interpretations thereof.

Cold weather humidification, or some lifestyles that produce excessive moisture, may cause condensation to occur if the absolute humidity of the indoor air is too high for the momentary circumstances. Condensation can occur on surfaces or concealed within the structure, and can lead to mold, mildew, frost damage, and moisture damage. The software does not perform calculations for the estimation or detection of possible condensation problems, and it is the designers (i.e. software users) responsibility to do so independently if required.

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.

Project Information

Project #: L211
 Name: Matthew Holmes
 Location: 10403, Y1A7A1, Whitehorse, Yukon, Canada

Notes:


Design Conditions and Summary

| | | | |
|--------------------------|-----------------------------|---------------------------|---------------|
| Load Calculation Method: | CSA F280-12 | Component Losses: | 14,206 Btu/hr |
| Design Location: | Whitehorse, Yukon Territory | Infiltration/Ventilation: | 12,896 Btu/hr |
| Outdoor Temperature: | -41.8 °F | Radiant Back Losses: | 2,131 Btu/hr |
| Floorplans / Levels: | | Total Heating Load: | 29,233 Btu/hr |
| Ground Floor | 1,000 ft ² | | |
| Main Floor | 1,066 ft ² | Radiant Heating: | 26,752 Btu/hr |
| Total Area: | 2,066 ft ² | Radiant Back Losses: | 2,131 Btu/hr |
| | | Other: | 350 Btu/hr |
| | | Total Heating Load: | 29,233 Btu/hr |

Radiant Panel Details

Panel Type #1 - Embedded Slab


| | |
|---------------------------------------|--------------------------------------|
| Slab Thickness: | 4.0 in |
| Tube Depth: | 2.5 in |
| Slab R per Inch (Embedding Material): | 0.15 °F•ft ² •hr/(Btu•in) |
| Spacing: | 10 in |
| Floorplans: | |
| Ground Floor | 798 ft ² |



Note: Tube depth is measured from top of embedded layer to the centerline of the tubing.

Panel Type #2 - Concrete Thin Slab

| | |
|-----------------------|--------------------------------------|
| Over-pour Thickness: | 2.0 in |
| Over-pour R per Inch: | 0.15 °F·ft ² ·hr/(Btu·in) |
| Sub-Floor Thickness: | 0.750 in |
| Sub-Floor Rv: | 0.9 hr·ft ² ·°F/btu |
| Joist Construction: | Joist 2"x10" pine, 16" OC |
| Joist Spacing: | 16 in |
| Joist Insulation Rv: | 5.0 hr·ft ² ·°F/btu |
| Insulation Rv | 5.0 hr·ft ² ·°F/btu |
| Spacing: | 10 in |
| Floorplans: | |
| Main Floor | 831 ft ² |

**Disclaimers**

The calculated values shown in this report are based on the data input by the user of the software. Inaccurate or erroneous data input will result in inaccurate or erroneous results. You are strongly advised to review all input data carefully, and to have the calculated results reviewed by an experienced heating professional to ensure reasonableness and suitability for your application.

IN NO EVENT WILL AVENIR SOFTWARE INC. ("AVENIR") OR ITS AFFILIATES BE LIABLE UNDER ANY CONTRACT, NEGLIGENCE, STRICT LIABILITY OR OTHER LEGAL OR EQUITABLE THEORY FOR ANY CONSEQUENTIAL, INCIDENTAL, INDIRECT OR SPECIAL OR PUNITIVE DAMAGES WHATSOEVER (INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, LOSS OF BUSINESS INFORMATION OR DATA AND THE LIKE), EVEN IF SUCH PARTY HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES. AVENIR'S CUMULATIVE LIABILITY FROM ANY CAUSE RELATED TO OR ARISING FROM THE USE THIS REPORT, AND REGARDLESS OF THE FORM OF THE ACTION, SHALL BE LIMITED TO NO GREATER THAN THE AMOUNT OF FEES PAID TO AVENIR UNDER THE SOFTWARE LICENSE AGREEMENT.