



# Load Short Form

## Entire House

### WebREPS

Job: 738 Lockwood Road  
 Date: October 31, 2023  
 By: Kenneth D. Puzinas  
 Plan: 738 Lockwood Road

1880 82nd Ave., Vero Beach, FL 32966 Phone: 800-810-3280 Email: manualj@webrepsusa.com

## Project Information

For: Eric Umbarger, MUSE  
 738 Lockwood Road, Marathon, NY 13803  
 Phone: 540.645.3635  
 Email: ETUmbarger@gmail.com

## Design Information

	Htg	Clg	Method	Infiltration	Simplified
Outside db (°F)	6	86			
Inside db (°F)	70	75	Construction quality		Tight
Design TD (°F)	64	11	Fireplaces		0
Daily range	-	M			
Inside humidity (%)	50	50			
Moisture difference (gr/lb)	51	28			

### HEATING EQUIPMENT

Make ACIQ  
 Trade ACIQ Series  
 Model ACIQ-48-HPB  
 AHRI ref 208106637

Efficiency 9.4 HSPF2  
 Heating input  
 Heating output 50000 Btuh @ 47°F  
 Temperature rise 36 °F  
 Actual air flow 1312 cfm  
 Air flow factor 0.023 cfm/Btuh  
 Static pressure 0.60 in H2O  
 Space thermostat  
 Capacity balance point = 0 °F

### COOLING EQUIPMENT

Make ACIQ  
 Trade ACIQ Series  
 Cond ACIQ-48-HPB  
 Coil ACIQ-48-AHB  
 AHRI ref 208106637

Efficiency 8.2 EER2, 15.6 SEER2  
 Sensible cooling 34310 Btuh  
 Latent cooling 12690 Btuh  
 Total cooling 47000 Btuh  
 Actual air flow 1312 cfm  
 Air flow factor 0.047 cfm/Btuh  
 Static pressure 0.60 in H2O  
 Load sensible heat ratio 0.73

Backup:  
 Input = 15 kW, Output = 51182 Btuh, 100 AFUE

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
LNDRY	88	1777	1904	41	90
CL 1	17	0	0	0	0
BEDRM 1	138	4020	1986	93	94
HALL	160	1853	2282	43	108
BATH	81	977	688	23	33
BEDROOM 2	121	2989	1586	69	75
CL 2	30	0	0	0	0
UTILITY	35	0	0	0	0
M CL	35	0	0	0	0
M BEDROOM	821	10956	4614	253	218
M BATH	120	1907	682	44	32
PNTY	29	3817	48	88	2
CL	10	0	0	0	0
UP	29	0	0	0	0

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

CLO	14	0	0	0	0
LIVING ROOM	333	7238	4352	167	206
DINING	135	2791	4960	64	235
KITCHEN	147	742	2523	17	119
PDR	30	0	0	0	0
TACK RM	124	17821	2118	411	100
Entire House	2496	56889	27742	1312	1312
Other equip loads		8526	2311		
Equip. @ 1.00 RSM			30053		
Latent cooling			11209		
TOTALS	2496	65414	41262	1312	1312

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



## Project Information

**For:** Eric Umbarger, MUSE  
 738 Lockwood Road, Marathon, NY 13803  
 Phone: 540.645.3635  
 Email: ETUmbarger@gmail.com

**Notes:** 738 Lockwood Road Marathon, NY 13803

## Design Information

**Weather:** Ithaca Tompkins Regional, NY, US

### Winter Design Conditions

Outside db 6 °F  
 Inside db 70 °F  
 Design TD 64 °F

### Summer Design Conditions

Outside db 86 °F  
 Inside db 75 °F  
 Design TD 11 °F  
 Daily range M  
 Relative humidity 50 %  
 Moisture difference 28 gr/lb

### Heating Summary

Structure 56889 Btuh  
 Ducts 0 Btuh  
 Central vent (SER=50% 105 cfm) 3542 Btuh  
 Energy recovery  
 Humidification 4984 Btuh  
 Piping 0 Btuh  
 Equipment load 65414 Btuh

### Sensible Cooling Equipment Load Sizing

Structure 27742 Btuh  
 Ducts 0 Btuh  
 Central vent (SER=50% 105 cfm) 604 Btuh  
 Energy recovery  
 Blower 1707 Btuh  
 Use manufacturer's data y  
 Rate/swing multiplier 1.00  
 Equipment sensible load 30053 Btuh

### Infiltration

Method Simplified  
 Construction quality Tight  
 Fireplaces 0

### Latent Cooling Equipment Load Sizing

Structure 10244 Btuh  
 Ducts 0 Btuh  
 Central vent (LER=50% 105 cfm) 965 Btuh  
 Energy recovery  
 Equipment latent load 11209 Btuh

	Heating	Cooling
Area (ft <sup>2</sup> )	2496	2496
Volume (ft <sup>3</sup> )	26215	26215
Air changes/hour	0.15	0.08
Equiv. AVF (cfm)	66	35

**Equipment Total Load (Sen+Lat)** 41262 Btuh  
 Req. total capacity at 0.73 SHR 3.4 ton

### Heating Equipment Summary

Make ACIQ  
 Trade ACIQ Series  
 Model ACIQ-48-HPB  
 AHRI ref 208106637

Efficiency 9.4 HSPF2  
 Heating input  
 Heating output 50000 Btuh @ 47°F  
 Temperature rise 36 °F  
 Actual air flow 1312 cfm  
 Air flow factor 0.023 cfm/Btuh  
 Static pressure 0.60 in H2O  
 Space thermostat  
 Capacity balance point = 0 °F

### Cooling Equipment Summary

Make ACIQ  
 Trade ACIQ Series  
 Cond ACIQ-48-HPB  
 Coil ACIQ-48-AHB  
 AHRI ref 208106637

Efficiency 8.2 EER2, 15.6 SEER2  
 Sensible cooling 34310 Btuh  
 Latent cooling 12690 Btuh  
 Total cooling 47000 Btuh  
 Actual air flow 1312 cfm  
 Air flow factor 0.047 cfm/Btuh  
 Static pressure 0.60 in H2O  
 Load sensible heat ratio 0.73

Backup:  
 Input = 15 kW, Output = 51182 Btuh, 100 AFUE

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



## Project Information

For: Eric Umbarger, MUSE  
 738 Lockwood Road, Marathon, NY 13803  
 Phone: 540.645.3635  
 Email: ETUmbarger@gmail.com

## Cooling Equipment

### Design Conditions

Outdoor design DB:	85.9°F	Sensible gain:	30053	Btuh	Entering coil DB:	76.7°F
Outdoor design WB:	71.1°F	Latent gain:	11209	Btuh	Entering coil WB:	63.2°F
Indoor design DB:	75.0°F	Total gain:	41262	Btuh		
Indoor RH:	50%	Estimated airflow:	1312	cfm		

### Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP			
Manufacturer:	ACIQ	Model:	ACIQ-48-HPB+ACIQ-48-AHB	
Actual airflow:	1312	cfm		
Sensible capacity:	34310	Btuh	114%	of load
Latent capacity:	12690	Btuh	113%	of load
Total capacity:	47000	Btuh	114%	of load SHR: 73%

## Heating Equipment

### Design Conditions

Outdoor design DB:	6.1°F	Heat loss:	65414	Btuh	Entering coil DB:	67.4°F
Indoor design DB:	70.0°F					


### Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	ACIQ	Model:	ACIQ-48-HPB+ACIQ-48-AHB		
Actual airflow:	1312	cfm			
Output capacity:	50000	Btuh	76%	of load	Capacity balance: 0 °F
Supplemental heat required:	15414	Btuh			Economic balance: 0 °F

Backup equipment type:	Elec strip			
Manufacturer:		Model:		
Actual airflow:	1312	cfm		
Output capacity:	15.0	kW	78%	of load Temp. rise: 0 °F

Meets all requirements of ACCA Manual S.





**Job #: 738 Lockwood Road**  
**Performed by Kenneth D. Puzinas for:**  
Eric Umbarger  
738 Lockwood Road  
Marathon, NY 13803  
Phone: 540.645.3635  
ETUmbarger@gmail.com

**WebREPS**  
1880 82nd Ave.  
Vero Beach, FL 32966  
Phone: 800-810-3280  
manualj@webrepsusa.com

Scale: 1 : 128  
Page 2  
Right-Suite® Universal 2023  
23.0.05 RSU16998  
2023-Dec-18 14:27:49  
...n\MUSE (Eric)\738 Lockwood 2.rup



# Duct System Summary

## Entire House

WebREPS

Job: 738 Lockwood Road  
 Date: October 31, 2023  
 By: Kenneth D. Puzinas  
 Plan: 738 Lockwood Road

1880 82nd Ave., Vero Beach, FL 32966 Phone: 800-810-3280 Email: manualj@webrepsusa.com

### Project Information

For: Eric Umbarger, MUSE  
 738 Lockwood Road, Marathon, NY 13803  
 Phone: 540.645.3635  
 Email: ETUmbarger@gmail.com

	Heating	Cooling
External static pressure	0.60 in H2O	0.60 in H2O
Pressure losses	0.24 in H2O	0.24 in H2O
Available static pressure	0.36 in H2O	0.36 in H2O
Supply / return available pressure	0.264 / 0.096 in H2O	0.264 / 0.096 in H2O
Lowest friction rate	0.093 in/100ft	0.093 in/100ft
Actual air flow	1312 cfm	1312 cfm
Total effective length (TEL)	386 ft	

### Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
BATH-A	c 688	23	33	0.114	4.0	0x0	ShMt	37.8	195.0	st1C
BEDRM 1	c 1986	93	94	0.146	5.0	0x0	ShMt	25.8	155.0	st1
BEDROOM 2	c 1586	69	75	0.106	5.0	0x0	ShMt	43.8	205.0	st1C
DINING	c 2480	32	117	0.111	6.0	0x0	ShMt	42.8	195.0	st1D
DINING-A	c 2480	32	117	0.122	6.0	0x0	ShMt	41.0	175.0	st1B
HALL	c 2282	43	108	0.121	6.0	0x0	ShMt	33.5	185.0	st1B
KITCHEN	c 2523	17	119	0.113	6.0	0x0	ShMt	34.3	200.0	st1C
LIVING ROOM	c 2176	83	103	0.140	6.0	0x0	ShMt	23.5	165.0	st1
LIVING ROOM-A	c 2176	83	103	0.124	6.0	0x0	ShMt	23.5	190.0	st1B
LNDRY	c 1904	41	90	0.150	5.0	0x0	ShMt	6.3	170.0	st1
M BATH-A	h 1907	44	32	0.113	4.0	0x0	ShMt	48.0	185.0	st1C
M BEDROOM	h 3652	84	73	0.131	5.0	0x0	ShMt	27.3	175.0	st1A
M BEDROOM-A	h 3652	84	73	0.136	5.0	0x0	ShMt	28.8	165.0	st1A
M BEDROOM-B	h 3652	84	73	0.108	5.0	0x0	ShMt	50.3	195.0	st1D
PNTY-A	h 3817	88	2	0.094	5.0	0x0	ShMt	40.3	240.0	st1E
TACK RM	h 8911	206	50	0.093	8.0	0x0	ShMt	58.3	225.0	st1E
TACK RM-A	h 8911	206	50	0.094	8.0	0x0	ShMt	47.5	235.0	st1E

## Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st1E	PeakAVF	499	102	0.093	719	10.8	10 x 10	ShtMetl	st1D
st1B	PeakAVF	927	880	0.093	695	13.6	12 x 16	ShtMetl	st1A
st1D	PeakAVF	616	293	0.093	633	11.6	10 x 14	ShtMetl	st1C
st1C	PeakAVF	768	552	0.093	691	12.6	10 x 16	ShtMetl	st1B
st1	PeakAVF	1312	1312	0.093	675	15.5	14 x 20	ShtMetl	
st1A	PeakAVF	1095	1025	0.093	704	14.4	14 x 16	ShtMetl	st1

## Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb3	0x0	297	251	102.6	0.093	672	9.0	0x 0		VIFx	rt1
rb1	0x0	1016	1062	92.8	0.103	601	18.0	0x 0		VIFx	rt1

## Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rt1	PeakAVF	1312	1312	0.093	602	20.0	0 x 0	ShtMetl	