

## Project Information

## Design Information

Weather: Trenton Mercer AP, NJ, US

### Winter Design Conditions

Outside db	<b>10</b> °F
Inside db	70 °F
Design TD	60 °F

### Summer Design Conditions

Outside db	<b>91</b> °F
Inside db	75 °F
Design TD	16 °F
Daily range	M
Relative humidity	50 %
Moisture difference	30 gr/lb

### Heating Summary

Structure	40884 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	40884 Btuh

### Sensible Cooling Equipment Load Sizing

Structure	17188 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
Blower	0 Btuh
Use manufacturer's data	y
Rate/swing multiplier	1.00
Equipment sensible load	17188 Btuh

### Infiltration

Method	Blower door
Shielding / stories	3 (partial) / 2
Pressure /ACH /AVF	50 Pa / 6.0 / 1766 cfm

### Latent Cooling Equipment Load Sizing

Structure	2743 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
Equipment latent load	2743 Btuh
<b>Equipment Total Load (Sen+Lat)</b>	<b>19930 Btuh</b>
Req. total capacity at 0.70 SHR	2.0 ton

	<b>Heating</b>	<b>Cooling</b>
Area (ft <sup>2</sup> )	2005	2005
Volume (ft <sup>3</sup> )	17655	17655
Air changes/hour	0.64	0.32
Equiv. AVF (cfm)	187	95

### Heating Equipment Summary

Make	n/a
Trade	n/a
Model	n/a
AHRI ref	n/a
Efficiency	n/a
Heating input	
Heating output	0 Btuh
Temperature rise	0 °F
Actual air flow	0 cfm
Air flow factor	0 cfm/Btuh
Static pressure	0 in H2O
Space thermostat	n/a

### Cooling Equipment Summary

Make	n/a
Trade	n/a
Cond	n/a
Coil	n/a
AHRI ref	n/a
Efficiency	n/a
Sensible cooling	0 Btuh
Latent cooling	0 Btuh
Total cooling	0 Btuh
Actual air flow	0 cfm
Air flow factor	0 cfm/Btuh
Static pressure	0 in H2O
Load sensible heat ratio	0

*Bold/italic values have been manually overridden*

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

## Project Information

## Design Information

Weather: Trenton Mercer AP, NJ, US

### Winter Design Conditions

Outside db	<b>10</b> °F
Inside db	70 °F
Design TD	60 °F

### Summer Design Conditions

Outside db	<b>91</b> °F
Inside db	75 °F
Design TD	16 °F
Daily range	M
Relative humidity	50 %
Moisture difference	30 gr/lb

### Heating Summary

Structure	8657 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
(none)	
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	8657 Btuh

### Sensible Cooling Equipment Load Sizing

Structure	4674 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
(none)	
Blower	0 Btuh
Use manufacturer's data	y
Rate/swing multiplier	1.00
Equipment sensible load	4674 Btuh

### Infiltration

Method	Blower door
Shielding / stories	3 (partial) / 2
Pressure /ACH /AVF	50 Pa / 6.0 / 1766 cfm

### Latent Cooling Equipment Load Sizing

Structure	894 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
(none)	
Equipment latent load	894 Btuh

	Heating	Cooling
Area (ft <sup>2</sup> )	365	365
Volume (ft <sup>3</sup> )	2916	2916
Air changes/hour	0.58	0.30
Equiv. AVF (cfm)	28	14

<b>Equipment Total Load (Sen+Lat)</b>	5569 Btuh
Req. total capacity at 0.92 SHR	0.4 ton

### Heating Equipment Summary

Make	Mitsubishi Electric
Trade	Mitsubishi Electric
Model	MXZ-SM36NAMHZ2
AHRI ref	
Efficiency	10 HSPF2
Heating input	
Heating output	9600 Btuh @ 47°F
Temperature rise	29 °F
Actual air flow	300 cfm
Air flow factor	0.035 cfm/Btuh
Static pressure	0 in H2O
Space thermostat	
Capacity balance point = 17 °F	

### Cooling Equipment Summary

Make	Mitsubishi Electric
Trade	Mitsubishi Electric
Cond	MXZ-SM36NAMHZ2
Coil	MSZ-FS09NA
AHRI ref	
Efficiency	16.0 EER2,29.8 SEER2
Sensible cooling	8280 Btuh
Latent cooling	720 Btuh
Total cooling	9000 Btuh
Actual air flow	300 cfm
Air flow factor	0.064 cfm/Btuh
Static pressure	0 in H2O
Load sensible heat ratio	0.84

*Bold/italic values have been manually overridden*

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

## Project Information

## Design Information

Weather: Trenton Mercer AP, NJ, US

### Winter Design Conditions

Outside db	<b>10</b> °F
Inside db	70 °F
Design TD	60 °F

### Summer Design Conditions

Outside db	<b>91</b> °F
Inside db	75 °F
Design TD	16 °F
Daily range	M
Relative humidity	50 %
Moisture difference	30 gr/lb

### Heating Summary

Structure	9565 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
(none)	
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	9565 Btuh

### Sensible Cooling Equipment Load Sizing

Structure	3838 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
(none)	
Blower	0 Btuh
Use manufacturer's data	y
Rate/swing multiplier	1.00
Equipment sensible load	3838 Btuh

### Infiltration

Method	Blower door
Shielding / stories	3 (partial) / 2
Pressure /ACH /AVF	50 Pa / 6.0 / 1766 cfm

### Latent Cooling Equipment Load Sizing

Structure	394 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
(none)	
Equipment latent load	394 Btuh

	Heating	Cooling
Area (ft <sup>2</sup> )	506	506
Volume (ft <sup>3</sup> )	4830	4830
Air changes/hour	0.47	0.24
Equiv. AVF (cfm)	38	19

<b>Equipment Total Load (Sen+Lat)</b>	4232 Btuh
Req. total capacity at 0.92 SHR	0.3 ton

### Heating Equipment Summary

Make	Mitsubishi Electric
Trade	Mitsubishi Electric
Model	MXZ-SM36NAMHZ2
AHRI ref	
Efficiency	10 HSPF2
Heating input	
Heating output	9600 Btuh @ 47°F
Temperature rise	29 °F
Actual air flow	300 cfm
Air flow factor	0.031 cfm/Btuh
Static pressure	0 in H2O
Space thermostat	
Capacity balance point = 19 °F	

### Cooling Equipment Summary

Make	Mitsubishi Electric
Trade	Mitsubishi Electric
Cond	MXZ-SM36NAMHZ2
Coil	MSZ-FS09NA
AHRI ref	
Efficiency	16.0 EER2,29.8 SEER2
Sensible cooling	8280 Btuh
Latent cooling	720 Btuh
Total cooling	9000 Btuh
Actual air flow	300 cfm
Air flow factor	0.078 cfm/Btuh
Static pressure	0 in H2O
Load sensible heat ratio	0.91

*Bold/italic values have been manually overridden*

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

## Project Information

## Design Information

Weather: Trenton Mercer AP, NJ, US

### Winter Design Conditions

Outside db	<b>10</b> °F
Inside db	70 °F
Design TD	60 °F

### Summer Design Conditions

Outside db	<b>91</b> °F
Inside db	75 °F
Design TD	16 °F
Daily range	M
Relative humidity	50 %
Moisture difference	30 gr/lb

### Heating Summary

Structure	11469 Btuh
Ducts	0 Btuh
Central vent (0 cfm) (none)	0 Btuh
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	11469 Btuh

### Sensible Cooling Equipment Load Sizing

Structure	5040 Btuh
Ducts	0 Btuh
Central vent (0 cfm) (none)	0 Btuh
Blower	0 Btuh
Use manufacturer's data	y
Rate/swing multiplier	1.00
Equipment sensible load	5040 Btuh

### Infiltration

Method	Blower door
Shielding / stories	3 (partial) / 2
Pressure /ACH /AVF	50 Pa / 6.0 / 1766 cfm

	<b>Heating</b>	<b>Cooling</b>
Area (ft <sup>2</sup> )	419	419
Volume (ft <sup>3</sup> )	4185	4185
Air changes/hour	0.66	0.33
Equiv. AVF (cfm)	46	23

### Latent Cooling Equipment Load Sizing

Structure	677 Btuh
Ducts	0 Btuh
Central vent (0 cfm) (none)	0 Btuh
Equipment latent load	677 Btuh

<b>Equipment Total Load (Sen+Lat)</b>	<b>5717 Btuh</b>
Req. total capacity at 0.83 SHR	0.5 ton

### Heating Equipment Summary

Make	Mitsubishi Electric
Trade	Mitsubishi Electric
Model	MXZ-SM36NAMHZ2
AHRI ref	
Efficiency	10.4 HSPF2
Heating input	
Heating output	12300 Btuh @ 47°F
Temperature rise	28 °F
Actual air flow	400 cfm
Air flow factor	0.035 cfm/Btuh
Static pressure	0 in H2O
Space thermostat	
Capacity balance point = 15 °F	

### Cooling Equipment Summary

Make	Mitsubishi Electric
Trade	Mitsubishi Electric
Cond	MXZ-SM36NAMHZ2
Coil	MSZ-FS12NA
AHRI ref	
Efficiency	13.8 EER2, 26.3 SEER2
Sensible cooling	9960 Btuh
Latent cooling	2040 Btuh
Total cooling	12000 Btuh
Actual air flow	400 cfm
Air flow factor	0.079 cfm/Btuh
Static pressure	0 in H2O
Load sensible heat ratio	0.88

*Bold/italic values have been manually overridden*

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

## Project Information

## Design Information

Weather: Trenton Mercer AP, NJ, US

### Winter Design Conditions

Outside db	<b>10</b> °F
Inside db	70 °F
Design TD	60 °F

### Summer Design Conditions

Outside db	<b>91</b> °F
Inside db	75 °F
Design TD	16 °F
Daily range	M
Relative humidity	50 %
Moisture difference	30 gr/lb

### Heating Summary

Structure	11193 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
(none)	
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	11193 Btuh

### Sensible Cooling Equipment Load Sizing

Structure	4986 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
(none)	
Blower	0 Btuh
Use manufacturer's data	y
Rate/swing multiplier	1.00
Equipment sensible load	4986 Btuh

### Infiltration

Method	Blower door
Shielding / stories	3 (partial) / 2
Pressure /ACH /AVF	50 Pa / 6.0 / 1766 cfm

### Latent Cooling Equipment Load Sizing

Structure	777 Btuh
Ducts	0 Btuh
Central vent (0 cfm)	0 Btuh
(none)	
Equipment latent load	777 Btuh

	<b>Heating</b>	<b>Cooling</b>
Area (ft <sup>2</sup> )	716	716
Volume (ft <sup>3</sup> )	5724	5724
Air changes/hour	0.78	0.40
Equiv. AVF (cfm)	75	38

<b>Equipment Total Load (Sen+Lat)</b>	5764 Btuh
Req. total capacity at 0.82 SHR	0.5 ton

### Heating Equipment Summary

Make	Mitsubishi Electric
Trade	Mitsubishi Electric
Model	SUZ-KA09NAHZ*
AHRI ref	213362132
Efficiency	9.9 HSPF2
Heating input	
Heating output	12000 Btuh @ 47°F
Temperature rise	37 °F
Actual air flow	300 cfm
Air flow factor	0.027 cfm/Btuh
Static pressure	0.60 in H2O
Space thermostat	
Capacity balance point = 20 °F	

### Cooling Equipment Summary

Make	Mitsubishi Electric
Trade	Mitsubishi Electric
Cond	SUZ-KA09NAHZ*
Coil	PEAD-A09AA9
AHRI ref	213362132
Efficiency	13.4 EER2, 19 SEER2
Sensible cooling	7380 Btuh
Latent cooling	1620 Btuh
Total cooling	9000 Btuh
Actual air flow	300 cfm
Air flow factor	0.060 cfm/Btuh
Static pressure	0.60 in H2O
Load sensible heat ratio	0.87

*Bold/italic values have been manually overridden*

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.