

Certificate



Certificate no.

CU 72228429 01

License Holder:

Apollo Heat Pumps

Manufacturing Plant:

-SOS-CN22DYC5 001

Test report no.: USA-SOS CN22DYC5 002

Client Reference: Apollo Heat Pumps

Tested to:

UL 1995:2015 R8.18
CSA C22.2 No. 236-15

Certified Product: Air to Water Heat Pump

License Fee - Units

Model Designation: 1) AP-EVI-DC-3.5T 2) AP-EVI-DC-5T
3) AP-EVI-DC-6T

8

Trademark : APOLLO

Rated Voltage: 220-240Vac, 60Hz

Running Current (Max Load): 1) 16.23A; 2) 29.67A; 3) 38.05A

Con.

8

Licensed Test mark:



Date of Issue
(day/mo/yr)

23/11/2022

Certificate



Certificate no.

CU 72228429 02

License Holder:

Apollo Heat Pumps

Manufacturing Plant:

-SOS-CN22DYC5 001

Test report no.: USA-SOS CN22DYC5 002

Client Reference: Apollo Heat Pumps

Tested to:

UL 1995:2015 R8.18
CSA C22.2 No. 236-15

Certified Product: Air to Water Heat Pump

License Fee - Units

Con.

Input Power:

- 1) Cooling (DB: 43°C, Water inlet 20°C): 2.52KW;
Heating (DB: -20°C, Water inlet 50°C): 2.93KW;
Cooling Max Load: 3.43KW; Heating Max Load : 3.52KW
- 2) Cooling (DB: 43°C, Water inlet 20°C): 4.12KW;
Heating (DB: -20°C, Water inlet 50°C): 5.92KW;
Cooling Max Load: 6.11KW; Heating Max Load : 6.52KW
- 3) Cooling (DB: 43°C, Water inlet 20°C): 6.32KW;
Heating (DB: -20°C, Water inlet 50°C): 7.53KW;
Cooling Max Load: 8.34KW; Heating Max Load : 8.36KW

Licensed Test mark:



**Date of Issue
(day/mo/yr)**

23/11/2022

Date : 2022/11/23

Apollo Heat Pumps

Attn: Apollo Heat Pumps (Private Email)

Re. : CU US + Canada Certificate

Type of Equipment : Air to Water Heat Pump
Model Designation : See Certificate
Certificate No. : CU 72228429 0001
File No. : CN22DYC5 002
Engineer/Contact : Sven Olaf Steinke
Standard(s) : UL 1995:2015 R8.18
CSA C22.2 No. 236-15

Dear Madame or Sir,

The above referenced technical equipment has been tested and was found to be in compliance with the listed test requirement(s). Enclosed, please find the TUV Rheinland approval document No. CU 72228429 0001. It authorizes you to label the listed product(s) with the TUV Rheinland Mark identified in the approval document. For compliance, the Test Mark must be on the approved unit.

Your product is subject to regular factory follow-up inspections as well as annual certificate and factory registration fees.

In using the TUV Rheinland Mark you are obligated to comply with the TUV Rheinland of North America Service Agreement.

If we can be of any further assistance to you, please do not hesitate to contact us.

Sincerely yours,
Certification Body



Dipl.-Ing. Univ. S. O. Steinke
QA Certification Officer

Enclosure