

Garage Attic
 Heating: 2784 BTUh @100%
 Cooling: 1315 BTUh @40%
 Briza-12 BZMW.04114512
 2-pipe /002
 Traffic White (.33)
 RAL 9016
 JDPC.002
 Flow: 0.18

Jaga Power Supply
 7990.054 24 VDC
 Quantity 1

Manifold 4 – Garage Fan Coil
 1 Zone + 2 spare
 Cross-Linear-X Zone control
 Honeywell T10+
 Flow Rate: 0.25 GPM
 Head Loss: 0.5 ft

CERV2/Geobost – 100 - 200 CFM
 1" Copper Stubs
 Heating: 5,000 BTUh
 Cooling: 7,500 BTUh
 Flow rate: 1.0 GPM
 Head Loss: 12,75 ft

Manifold 3 – House Fan Coil
 3 zones+ 1 spare
 Cross-Linear-X Zone control
 Honeywell T10+
 Flow Rate: 1.25 GPM
 Head Loss: 1.5 FT

Jaga Power Supply
 7990.054 24 VDC
 Quantity 1

